Environmental Health Unit

Manitoba
Health
Public Health

MG 2688 (Rev. 4/02)



MANITOBA HEALTH

HEALTHY LIVING AND HEALTH PROGRAMS

PUBLIC HEALTH BRANCH

COMMUNITY WATER FLUORIDATION PROGRAM

2005 / 2006

Prepared by:
ALS Laboratory Group
formerly
Enviro-Test Laboratories
(Manitoba Technology Centre Ltd.)
in conjunction with
Manitoba Health

2007-01621/

TABLE OF CONTENTS

INTRODUCTION 1

I. STATUS OF FLUORIDATION IN MANITOBA 2
COMMUNITIES WITH A FLUORIDATED WATER SUPPLY TABLE I 3-5

II. FLUORIDATION GRANT
A. OVERVIEW 6
B. NEW PARTICIPANTS AND UPGRADES 6

III. EQUIPMENT
A. OVERVIEW 7
B. FLUORIDATION SYSTEMS 7
C. OPERATING PROBLEMS 8

IV. MONITORING PROGRAM
A. OVERVIEW 9
B. RESULTS 10

BI-WEEKLY SAMPLING RESULTS - 2005 / 2006 SUMMARY TABLE II 11

C. CERTIFICATES 2005 / 2006 12
EXCELLENCE RECIPIENTS 13
COMMENDATION RECIPIENTS 14

V. MANITOBA WATER SERVICES BOARD 15

VI. SUPPORT SERVICES 16

VII. FLUORIDE CONTROL DATA - 2005 / 2006 17
(Listed by location of the water treatment plant.)

FLUORIDE CONTROL DATA - 2005 / 2006 SUMMARY - TABLE III 18-19
FLUORIDE CONTROL DATA KEY 20

AUSTIN 21
BALDUR 22
BENITO 23
BINSCARTH 24
BIRTLE 25
BOISSEVAIN 26
BRANDON 27
CARMAN 28
CARTIER REGIONAL 29
CHURCHILL 30

TABLE OF CONTENTS continued

Page

CRANBERRY PORTAGE 31
CROSS LAKE RESERVE 32
DAUPHIN 33
DELORAINE 34
FLIN FLON 35
GILBERT PLAINS 36
GILLAM 37
GIMLI 38
GIMLI INDUSTRIAL PARK 39
GLADSTONE 40
GRISWOLD SIOUX VALLEY BAND 41

HAMIOTA 42
HARTNEY 43
KILLARNEY 44
LETELLIER-RRRWTP 45
LONG PLAIN 46
MANITOU 47
MELITA 48
MINNEDOSA 49
MORDEN 50
MORRIS 51
NEEPAWA 52
NORWAY HOUSE COMMUNITY COUNCIL 53

PILOT MOUND 54
PINAWA 55
PORTAGE LA PRAIRIE 56
RESTON 57
RIVERS 58
ROBLIN 59
ROSSBURN 60
RUSSELL 61
SANFORD (RM MACDONALD) 62
SAPOTAWEYAK 63
SHILO 64
SOMERSET 65
SOURIS 66

STEINBACH 67
STEPHENFIELD 68
SWAN RIVER 69
THE PAS 70
TREHERNE 71
VIRDEN 72
WABOWDEN 73
WINKLER 74
WINNIPEG 75
WINNIPEGOSIS 76

INTRODUCTION

This report is a brief summary of the performance of Manitoba Health's Community Water Fluoridation Program for the 2005 / 2006 fiscal year.

I. STATUS OF FLUORIDATION IN MANITOBA - 2005/2006

A total of fifty-six (56) water treatment plants provide fluoridated water to approximately eighty-nine (89) communities. Approximately 95% of the population served by a public water system receive fluoridated water. Population statistics are based on the 1996 census figures unless otherwise indicated. Included in the above statistics are an estimated number of rural residents who consume water transported from a fluoridated water supply.

Manitoba Health operates a province-wide fluoride level monitoring program for all fluoridating communities. All online water treatment plants participated in the monitoring program.

Manitoba Health offers a grant for communities wishing to install a fluoridation system in their communal water system. Assistance is provided in the design and selection of suitable fluoridation systems/equipment.

Training in equipment operation and maintenance, testing procedures, safety standards and monitoring protocol is provided initially to all communities. Technical assistance and support is then provided on an ongoing basis.

Manitoba Health

Summary

Province of Manitoba

Table 1

Communities with a Fluoridated Water Supply as of April 1, 2005

NOTE: Population statistics are from 1996 census except for those indicated by ** which are still 1991 figures and by * which are 1986 figures.**

Water Plant Location	Status	Population	Ministerial Approval	Dates On-Line	Background Level	Chemical Feed	Average F mg/L	Water Source	Water Plant Owner
AUSTIN	Region	1279***	88/12/15	88/12/15	0.19	Na2SiF6 (Dry)	1.1	River	RM
BALDUR	Village	341**	66/09/19	67/11/15	0.22	NaF 4 %	0.9	Well	RM
BENITO	Village	460	91/08/01	91/08/01	0.3	NaF 4 %	0.9	River	Village
BINSCARTH	Village	463	94/11/01	95/07/19	0.24	H2SiF6 25 %	0.8	Well	Village
BIRTLE	Town	720	89/05/04	87/11/07	0.26	NaF 4 %	0.8	Well	Town
BOISSEVAIN	Town	1544	56/11/05	57/01/11	0.2	NaF 4 %	0.9	SI	Town
BRANDON	City	39175	53/08/11	55/03/08	0.2	Na2SiF6 (Dry)	0.8	River	City
CARMAN	Town	2704	65/06/22	65/06/22	0.21	H2SiF6 25 %	0.8	River	Town
CARTIER REGIONAL	Region	N/A *	00/06/13	00/06/13	0	H2SiF6 25 %	1.0	River	Private
CHURCHILL	LGD	1089	94/11/01	95/10/04	< 0.10	H2SiF6 25 %	1.0	River	LGD
CRANBERRY PORTAGE	UVD	723	83/03/19	83/12/14	< 0.10	NaF 4 %	1.1	Lake	RM
CROSS LAKE RESERVE	Reserve	4000^	92/05/02	92/05/02	< 0.10	NaF 4 %	1.1	River	Reserve
DAUPHIN	Town	8226	57/08/02	80/05/03	0.14	H2SiF6 25 %	0.9	SI	Town
DELORAINE	Town	1041	67/07/28	68/09/24	0.16	NaF 4 %	1.0	SI	Town
FLIN FLON	City	6572	61/07/01	89/12/15	< 0.10	H2SiF6 25 %	1.0	Lake	City
GILBERT PLAINS	Village	748	89/02/22	89/02/22	0.19	NaF 4 %	0.8	Well	Village
GILLAM	LGD	1534	74/08/14	87/01/03	< 0.10	H2SiF6 25 %	1.0	River	LGD
GIMLI	RM	3124	87/05/01	69/04/18	0.45	NaF 4 %	1.0	Well	RM
GIMLI INDUSTRIAL PARK	Town	1574	63/08/01	63/12/23	0.43	NaF 4 %	1.0	Well	Town
GLADSTONE	Town	927	71/04/19	76/09/23	0.22	Na2SiF6 (Dry)	0.7	River	Town
GRISWOLD SIOUX VALLEY BAND	Reserve	1136	99/11/01	99/11/26	0.1	NaF 4 %	0.9	Well	Reserve
HAMIOTA	Village	847	70/05/27	70/08/17	0.29	NaF 4 %	1.1	Well	Town
HARTNEY	Town	462	64/01/02	64/12/16	0.2	NaF 4 %	0.8	Well	Town
KILLARNEY	Town	2208	60/10/12	60/10/25	0.19	NaF 4 %	0.9	Lake	Town
LETELLIER-RRRWTP	Region	3921**	89/05/04	87/05/13	0.17	H2SiF6 25 %	1.0	River	PVWC

KEY:

1. Status
CFB - Canadian Forces Base
LGD - Local Government District
UVD - Unincorporated Village District

2. Type of Chemical Feed
H2SIF6 - Fluorosilicic Acid
NaF - Sodium Fluoride
Na2SiF6 - Sodium Fluorsilicate (Dry)

3. Water Plant Owner
MWSB - Manitoba Water Services Board
PVWC - Pembina Valley Water Co-op
RM - Rural Municipality

4. Water Source
SI - Surface Impoundment

Manitoba Health

Summary

Province of Manitoba

Table 1

Communities with a Fluoridated Water Supply as of April 1, 2005

NOTE: Population statistics are from 1996 census except for those indicated by ** which are still 1991 figures and by *** which are 1986 figures.

Water Plant Location	Status	Population	Ministerial Approval	Dates On-Line	Background Level	Chemical Feed	Average F mg/L	Water Source	Water Plant Owner
LONG PLAIN	Reserve	597	94/03/02	94/03/02	0.23	NaF 4 %	0.8	Well	Reserve
MANITOU	Town	781	64/01/21	65/05/13	0.19	NaF 4 %	1.0	SI	Town
MELITA	Town	1152	89/05/04	87/02/14	0.18	NaF 4 %	0.8	Well	Town
MINNEDOSA	Town	2443	60/01/25	86/04/01	0.28	H2SiF6 25 %	0.8	Well	Town
MORDEN	Town	5689	68/09/09	69/11/17	0.32	H2SiF6 25 %	0.9	Lake	Town
MORRIS	Region	1645	89/05/04	89/02/27	0.22	H2SiF6 25 %	1.0	River	PVWC
NEEPAWA	Town	3301	63/06/10	63/07/10	0.24	Na2SiF6 (Dry)	0.8	Lake	Town
NORWAY HOUSE COMMUNITY COUNCIL	Town	2100	95/01/01	95/09/01	0.21	H2SiF6 25 %	1.3	River	Town
PILOT MOUND	Town	716	68/10/25	70/12/21	0.21	NaF 4 %	0.8	SI	Town
PINAWA	LGD	1672	63/11/26	64/01/14	0.08	H2SiF6 25 %	1.0	River	LGD
PORTAGE LA PRAIRIE	City	13077	57/12/20	58/01/13	0.2	H2SiF6 25 %	0.9	River	City
RESTON	Village	620**	67/09/13	68/11/26	0.13	NaF 4 %	1.0	Well	RM
RIVERS	Town	1117	68/06/07	86/10/27	0.18	NaF 4 %	1.0	Well	Town
ROBLIN	Town	1885	69/06/07	86/10/27	0.26	NaF 4 %	0.9	Well	Town
ROSSBURN	Town	580	89/05/04	77/12/05	0.1	NaF 4 %	0.9	Well	Town
RUSSELL	Town	1605	65/09/10	67/03/01	0.21	NaF 4 %	1.0	Well	Town
SANFORD (RM MACDONALD)	Region	1657***	89/11/21	89/11/21	0.1	H2SiF6 25 %	1.0	River	RM
SAPOTAWEYAK	Reserve	800	03/12/18	03/12/18	0.31	NaF 4 %	0.7	River	Reserve
SHILO	CFB	3200***	69/01/14	69/01/14	0.05	NaF 4 %	1.0	Well	CFB
SOMERSET	Town	534	04/03/01	04/05/01	.02	H2SiF6 25 %	0.8	Well	MSWB
SOURIS	Town	1613	62/07/11	63/11/05	0.19	NaF 4 %	0.9	River	Town
STEINBACH	City	8478	59/11/04	60/05/23	0.39	H2SiF6 25 %	0.8	Well	City
STEPHENFIELD	Region	800	98/12/01	99/02/01	0.2	H2SiF6 25 %	1.0	River	PVWC
SWAN RIVER	Town	3986	80/10/07	82/08/08	0.18	H2SiF6 25 %	1.0	Well	Town
THE PAS	Town	5945	64/07/20	64/07/23	0.15	H2SiF6 25 %	1.0	River	Town

KEY:

1. Status
CFB - Canadian Forces Base
LGD - Local Government District
UVD - Unincorporated Village District

2. Type of Chemical Feed
H2SIF6 - Fluorosilicic Acid
NaF - Sodium Fluoride
Na2SiF6 - Sodium Fluorsilicate (Dry)

3. Water Plant Owner
MWSB - Manitoba Water Services Board
PVWC - Pembina Valley Water Co-op
RM - Rural Municipality

4. Water Source
SI - Surface Impoundment

Manitoba Health

Province of Manitoba

Table 1

Summary

Communities with a Fluoridated Water Supply as of April 1, 2005

NOTE: Population statistics are from 1996 census except for those indicated by ** which are still 1991 figures and by * which are 1986 figures.**

Water Plant Location	Status	Population	Ministerial Approval	Dates On-Line	Background Level	Chemical Feed	Average F mg/L	Water Source	Water Plant Owner
TREHERNE	Town	675	72/11/10	73/06/11	0.32	Na2SiF6 (Dry)	0.9	Well	Town
VIRDEN	Town	2956	71/01/11	71/04/08	0.44	NaF 4 %	0.9	Well	Town
WABOWDEN	Village	700**	89/06/30	89/06/30	< 0.10	H2SiF6 25 %	1.1	Lake	UVD
WINKLER	City	7241	64/01/21	64/06/24	0.26	H2SiF6 25 %	0.9	Well	City
WINNIPEG	City	618477	56/07/20	56/12/28	0.1	H2SiF6 25 %	0.9	Lake	City
WINNIPEGOSIS	Village	730	89/05/04	88/08/10	0.15	NaF 4 %	0.9	Well	MSWB
*OTHER		1148***							

NOTES:

-The Red River Regional Water Treatment Plant in Letellier, Manitoba serves the following communities: Altona Rural Water Co-op, Dominion City,Gnadenfeld, Gnadenthal, Gretna Halbstadt-Marais Water Co-op, Horndean, Neubergthal, Plum Coulee, Rosenfeld, Roseau River Reserve, Sommerfeld, Town of Altona, Morden, Winkler and St. Jean

-The Regional Plant in Sanford also serves the communities of Brunkild, Domain, LaSalle, Oak Bluff and Starbuck

^ Cross Lake Community and Cross Lake Reserves combined have an approximate population of 4000.

* Cartier Regional provides water for several communities including Headingley, Elie, St. Eustache, St. Francis etc.

KEY:

1. Status
CFB - Canadian Forces Base
LGD - Local Government District
UVD - Unincorporated Village District

2. Type of Chemical Feed
H2SIF6 - Fluorosilicic Acid
NaF - Sodium Fluoride
Na2SiF6 - Sodium Fluorsilicate (Dry)

3. Water Plant Owner
MWSB - Manitoba Water Services Board
PVWC - Pembina Valley Water Co-op
RM - Rural Municipality

4. Water Source
SI - Surface Impoundment

II.FLUORIDATION GRANT

Each fiscal year, grant monies are available through Manitoba Health. The grant is a one time award to communities initiating a fluoridation system.

A.OVERVIEW

1)OBJECTIVE:
To have all communal water systems in the Province fluoridated.

2)ELIGIBILITY:
Any community with an existing water treatment plant that currently does not have an optimal fluoride level in the water supply is eligible.

3)DESCRIPTION:
If a community is interested in this grant, contact can be made with Manitoba Health. Manitoba Health will provide information on the grant program, make formal contact with the community and assist in the design, installation and operation of the equipment. Once the system is operational, payment will be authorized to the community for the initial purchase and installation of the equipment. Assistance is provided with ongoing monitoring of the fluoride levels in the water supply.

4) FUNDING:
The grant is based on actual initial costs of purchase and installation of equipment as submitted by communities.

5) MINISTERIAL APPROVAL:
Approval is issued by the Minister of Health to communities operating fluoridation systems in accordance with the regulations under the Manitoba Public Health Act.

B.NEW PARTICIPANTS AND UPGRADES

1) Negotiations are underway with several new Reserve Communities.

2) Several communities received small upgrade grants.

3) Gimli off-line July 2005

III. EQUIPMENT

Fluoridation systems are periodically monitored and reassessed for efficiency. Efforts are made to upgrade older equipment to more efficient systems.

A. OVERVIEW

Water treatment plants are visited on a periodic basis for the purpose of encouraging preventive maintenance of the fluoridation systems.

Ongoing assistance is provided to ensure that adequate maintenance and safety practices are being followed. Testing procedures are also reviewed to ensure accurate monitoring of fluoride levels.

B. FLUORIDATION SYSTEMS

There are four types of fluoridation systems available. They are as follows:

a) Acid Feed

This system utilizes fluorosilicic acid (H_2SiF_6) as the chemical feed.

b) Batch Mix

This system utilizes sodium fluoride (NaF) as the chemical feed. This system is labour intensive and communities utilizing this system are encouraged to upgrade to either an acid feed or an upflow saturator system.

c) Dry Feed

This system utilizes sodium fluorosilicate (Na_2SiF_6) as the chemical feed. These systems were designed and installed in the 1950's and 1960's for larger treatment facilities. All remaining are fully functional with few operating problems.

d) Upflow Saturator

This system utilizes sodium fluoride (NaF) in a 4% solution as the chemical feed.

C. OPERATING PROBLEMS

Temporary operating problems may occur from time to time and are usually related to one of the following:

a) obsolete or malfunctioning fluoride feed equipment
b) obsolete or defective testing equipment
c) incorrect testing procedures
d) equipment breakdown
e) improper maintenance
f) changeover to a new system

Occasionally, fluoridation problems are related to water plant problems which are rectified when the plant's problems are corrected.

IV. MONITORING PROGRAM

A. OVERVIEW

The purpose of this program is to ensure that the recommended level for fluoride concentration is maintained in Manitoba's drinking water. All operating systems participated in the monitoring program.

1) Operating Parameters
Manitoba Health identifies an operating range and an optimum level for fluoride concentration in drinking water. The optimum is 1 part per million (ppm) or 1 milligram per litre (mg/L). The operating range for 2005 / 2006 was set at 0.80 ppm as a minimum with 1.20 ppm as a maximum.

Water treatment plant operators are encouraged to maintain fluoride concentrations within the specified range.

Manitoba Health provides a schedule for bi-weekly monitoring periods. A sampling year consists of 26 periods.

2) Supplies
Manitoba Health provides Fluoridation Control Record forms to the plants, to be submitted with the samples. Manitoba Health also provides sampling bottles, fluoride standard solution, spadns (reagent) and shipping containers to the plants, through ALS Laboratory Group. All are necessary for daily testing and bi-weekly sample submission.

3) Sample Submission
Samples are collected on a daily basis, tested on-site and results are recorded by the water treatment plant operator. A 14 day composite sample (approximately one litre) is submitted bi-weekly by the community for analysis. A record of chemical feed data (Fluoridation Control Record) is submitted with the sample.

4) Analysis
ALS Laboratory Group, located in Winnipeg, receives the samples and conducts the analysis. The results are reported to the individual water treatment plant operators and to Manitoba Health.

5) Monitoring
Manitoba Health monitors the levels, makes recommendations, and provides technical assistance accordingly.

6) Reporting
Communities receive an annual report of their plant's operating record. On a periodic and/or as required basis, reports are provided during the operating year.

B. RESULTS

In 2005 / 2006, out of a possible 1,438 samples, 1,401 bi-weekly samples were received for a submission rate of 97.4%.

Of the total submitted 1,181 or 84.3% were within the recommended range for fluoride concentration.

The number of samples found to be above the range was 35, representing 2.5% of the total.

There were 185 samples found to be below the range representing 13.2% of all samples submitted.

Bi-Weekly Sampling Results Summary 2005 / 2006

Table 2

Town	No. of Samples Within Limits	No. of Samples Above Limits	No. of Samples Below Limits	No. of Samples Submitted	No. of Samples Possible
AUSTIN	22	3	1	26	26
BALDUR	26	0	0	26	26
BENITO	24	0	2	26	26
BINSCARTH	16	0	9	25	26
BIRTLE	14	2	10	26	26
BOISSEVAIN	26	0	0	26	26
BRANDON	22	0	4	26	26
CARMAN	13	0	13	26	26
CARTIER REGIONAL	24	1	0	25	26
CHURCHILL	26	0	0	26	26
CRANBERRY PORTAGE	26	0	0	26	26
CROSS LAKE RESERVE	23	2	0	25	26
DAUPHIN	24	0	2	26	26
DELORAINE	26	0	0	26	26
FLIN FLON	26	0	0	26	26
GILBERT PLAINS	19	0	7	26	26
GILLAM	24	0	2	26	26
GIMLI	3	0	0	3	8
GIMLI INDUSTRIAL PARK	23	0	0	23	26
GLADSTONE	10	0	16	26	26
GRISWOLD SIOUX VALLEY BAND	13	1	3	17	26
HAMIOTA	21	4	0	25	26
HARTNEY	20	0	6	26	26
KILLARNEY	25	0	1	26	26
LETELLIER-RRRWTP	26	0	0	26	26
LONG PLAIN	14	1	11	26	26
MANITOU	26	0	0	26	26
MELITA	23	0	3	26	26
MINNEDOSA	23	0	2	25	26
MORDEN	24	1	1	26	26
MORRIS	25	1	0	26	26
NEEPAWA	11	1	14	26	26
NORWAY HOUSE COMMUNITY COUNCIL	8	6	0	14	26
PILOT MOUND	19	0	7	26	26
PINAWA	22	2	2	26	26
PORTAGE LA PRAIRIE	25	0	1	26	26
RESTON	23	2	1	26	26
RIVERS	25	1	0	26	26
ROBLIN	26	0	0	26	26
ROSSBURN	21	0	4	25	26
RUSSELL	26	0	0	26	26
SANFORD (RM MACDONALD)	25	0	1	26	26
SAPOTAWEYAK	4	0	22	26	26
SHILO	25	0	0	25	26
SOMERSET	11	1	14	26	26
SOURIS	21	1	3	25	26
STEINBACH	18	0	8	26	26
STEPHENFIELD	25	0	1	26	26
SWAN RIVER	26	0	0	26	26
THE PAS	25	0	1	26	26
TREHERNE	24	0	2	26	26
VIRDEN	22	0	4	26	26
WABOWDEN	20	5	1	26	26
WINKLER	26	0	0	26	26
WINNIPEG	26	0	0	26	26
WINNIPEGOSIS	20	0	6	26	26

C. CERTIFICATES

Manitoba Health annually presents certificates to recognize water treatment plant operators who have maintained a high standard of operating efficiency for a fluoridation system.

To be eligible for a certificate, a plant must be participating for 50% of the sampling year.

For the 2005 / 2006 sampling year this represented 13 periods.

There were 56 plants eligible for the certificates in 2005 / 2006. The Altona plant is not eligible for the certificate program because it is a sampling location only.

1) CERTIFICATE OF EXCELLENCE

The selection criteria are:
A) 100% of bi-weekly samples must be submitted for the sampling year
and
B) 100% of submitted samples must be within the recommended operating range for fluoride concentration

In 2005 / 2006 certificates of excellence were presented to 19 water plant supervisors/operators. This represents 34% of the total number of eligible community fluoridation systems. Allowances are made on the presentation of certificates when justifiable explanations are provided.

2) CERTIFICATE OF COMMENDATION

The selection criteria are:
A) 85% or 22 out of 26 bi-weekly samples must be submitted for the sampling year, and
B) 90% of submitted samples must be within the recommended operating range for fluoride concentration.

In 2005 / 2006 certificates of commendation were presented to 22 water plant supervisors/operators. This represents 39% of the total number of eligible community fluoridation systems. Allowances are made on the presentation of certificates when justifiable explanations are provided.

The total number of certificates presented was 41 out of a possible 56. Thus, 73% of the operators/supervisors were awarded with recognition certificates.

Certificates of Excellence

2005 / 2006 Recipients

Recipient	Plant Location	Operating Authority
Raymond Lussier	BALDUR	RM
Barry Chinner	BOISSEVAIN	Town
William Ayotte	CHURCHILL	LGD
Darcy Rajczakowski	CRANBERRY PORTAGE	RM
Kent Corkish	DELORAINE	Town
Kevin Komarnicki	FLIN FLON	City
Kurt Henry	LETELLIER-RRRWTP	PVWC
Bob Barett	MANITOU	Town
Doug Campbell	PORTAGE LA PRAIRIE	City
Glen Reierson	ROBLIN	Town
Mark Moan	RUSSELL	Town
Trevor Richardson	SANFORD (RM MACDONALD)	Region
Bill Burke	SHILO	CFB
Paul Termeer	STEPHENFIELD	PVWC
Garry Kennedy	SWAN RIVER	Town
Ronald Stewart	THE PAS	Town
Ken Lawrence	TREHERNE	Town
Travis Duff	WINKLER	City
Frank DeVries	WINNIPEG	City

Certificates of Commendation

2005 / 2006 Recipients

Recipient	Plant Location	Operating Authority
Ed Sattler	AUSTIN	RM
Rick Kinaschuk	BENITO	Village
Brad McIntosh	BRANDON	City
Dave Pirt	CARTIER REGIONAL	Private
Lawrence McLeod	CROSS LAKE RESERVE	Reserve
Bill Brenner	DAUPHIN	Town
John McDonald	GILLAM	LGD
Richard Bezdietny	GIMLI INDUSTRIAL PARK	Town
Ken Curie	HAMIOTA	Town
Greg Morrison	HARTNEY	Town
Bob Reddaway	MELITA	Town
Frank Taylor	MINNEDOSA	Town
Al Spearman	MORDEN	Town
Shawn Lamb	KILLARNEY	Town
Richard Dupuis	MORRIS	PVWC
Ron McDowall	PINAWA	LGD
Ken Moore	RESTON	RM
Randy King	RIVERS	Town
Nick Antoniw	ROSSBURN	Town
Don Bodin and Kelvin Kowalchuk	SOURIS	Town
Jason Hiebert	STEINBACH	City
Norm Baxter	VIRDEN	Town

V. Manitoba Water Services Board

Manitoba Water Services Board owns a number of treatment facilities across Manitoba and provides water to communities.

In communities currently fluoridating, Manitoba Water Services Board works cooperatively with Manitoba Health to ensure that the requirements of the fluoridation monitoring system are met.

In communities wishing to fluoridate, Manitoba Water Services Board works in conjunction with Manitoba Health to assess the water treatment facility design the fluoridation system and coordinate installation and start-up.

Manitoba Water Services Board plant operators are trained by Manitoba Health staff in proper testing, operating and maintenance procedures for their specific fluoridation systems.

VI. SUPPORT SERVICES

Manitoba Health wishes to acknowledge the support received from various groups and government departments which provided assistance with the performance of the Community Water Fluoridation Program:

i. Mayors, Community Councils, Waterworks Chairpersons, Band Councils, and especially water treatment plant operators and supervisors in all locations with community water fluoridation systems in operation.

ii. Manitoba Water Services Board for the cooperative efforts made to ensure Manitoba Health standards were observed in all fluoridating locations.

iii. ALS Laboratory Group for the provision of fluoride level analyses, the distribution of reagents, sample bottles and fluoride results to participating communities, the preparation of this report and other administrative services.

iv. Manitoba Water Stewardship for the provision of inspection and surveillance services in water plants, as well as consultation services.

v. Medical Services Branch, Health Canada for the promotion of fluoridation on Manitoba First Nation communities.

vi. Equipment manufacturers and suppliers for assistance with system design, especially Prairie Chem Inc. for promotion services and consultation assistance.

vii. Cochrane Engineering, design consultants, for consulting services.

All of the above individuals and agencies have been instrumental in the provision of this important preventive dental health measure to the citizens of Manitoba.

A special thank you to Helen Browne, administrative assistant, without whom this program would not run so well!

FOR FURTHER INFORMATION REGARDING MANITOBA'S COMMUNITY WATER FLUORIDATION PROGRAM PLEASE CONTACT:

Dr. Bernadette Mellon
Manitoba Health
Public Health Branch
Room 4068
300 Carlton Street
Winnipeg MB R3B 3M9

Telephone: (204) 788-6729
Fax: (204) 948-2040
Email: bdesmarais@gov.mb.ca

VII

FLUORIDE

CONTROL

DATA

2005 / 2006

Manitoba Health Fluoride Monitoring Program

Table 3

Fluoride Control Data Laboratory Results - 2005 / 2006 - Summary

The figures in this table reflect results of the testing of bi-weekly composite samples for fluoride concentration in parts per million

Location / Period Number	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
AUSTIN	1.0	1.1	0.9	0.9	0.7	0.9	0.9	1.0	1.0	1.0	1.1	1.1	1.0	1.0	1.0	1.1	1.0	1.1	1.0	0.9	1.2	1.3	1.5	1.5	1.0	1.1
BALDUR	0.8	1.1	0.9	1.0	0.9	0.8	0.9	1.0	1.0	1.1	0.9	0.9	0.9	0.9	0.9	0.9	0.9	1.1	0.9	0.8	0.9	0.9	1.0	0.9	0.8	0.8
BENITO	0.8	1.0	1.0	1.0	1.0	1.0	0.9	0.9	1.0	0.9	1.0	1.0	1.0	0.9	0.9	0.7	0.7	0.9	0.9	0.8	0.9	1.0	1.0	0.9	0.8	0.8
BINSCARTH		0.7	0.7	0.7	0.8	1.1	0.8	0.7	0.7	0.6	0.7	0.7	0.7	0.8	0.9	0.8	0.8	0.9	0.8	0.9	0.9	0.9	1.0	0.9	0.8	0.8
BIRTLE	1.2	1.1	1.0	1.0	1.0	0.5	1.8	1.2	1.2	1.1	1.3	0.5	0.8	1.2	1.2	1.1	1.0	1.1	0.6	0.3	0.3	0.3	0.3	0.2	0.2	0.3
BOISSEVAIN	0.9	0.8	0.9	1.1	0.9	0.9	0.9	0.9	0.9	1.0	0.9	1.0	1.0	1.0	1.0	0.9	0.9	1.1	0.9	0.8	1.0	1.0	1.0	1.0	0.9	0.9
BRANDON	1.1	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.8	1.0	0.9	0.9	0.9	0.8	0.8	0.9	0.8	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.7
CARMAN	0.7	1.1	0.7	0.9	0.7	0.7	0.7	0.8	0.9	0.7	0.8	0.8	0.9	0.9	1.0	0.8	0.7	0.7	0.6	0.6	0.7	0.7	0.8	0.8	0.7	0.8
CARTIER REGIONAL	1.1	1.2		1.1	1.3	1.1	1.2	1.2	1.2	1.2	1.1	1.2	1.0	1.0	1.0	1.0	1.0	1.1	0.9	0.8	1.0	0.9	0.9	0.8	0.8	0.9
CHURCHILL	0.9	1.1	1.0	1.1	1.0	1.1	1.1	1.0	1.1	1.1	1.1	1.1	1.0	1.0	1.1	0.9	0.9	1.1	0.9	0.9	1.1	1.2	1.0	1.0	0.9	0.9
CRANBERRY PORTAGE	0.9	1.1	1.0	1.2	1.0	1.0	1.2	1.1	1.0	1.0	1.0	1.1	1.1	1.2	1.2	1.0	1.0	1.1	1.0	0.9	1.1	1.1	1.1	0.9	1.0	1.1
CROSS LAKE RESERVE	1.1	1.0	1.0	1.2	1.1	1.1	0.8	1.0	1.1	1.0	1.2	1.1	1.1	1.2	1.1	0.9	0.9		1.1	0.9	1.1	1.1	1.4	1.3	1.1	1.0
DAUPHIN	0.9	0.7	0.2	1.1	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	1.0	1.0	0.9	0.9	0.8	0.8	0.8	0.8	1.1	1.0	1.0	1.0	1.0	0.8
DELORAINE	0.9	1.1	1.0	1.0	0.9	0.9	0.9	0.9	0.9	0.9	0.9	1.1	1.1	1.0	1.1	1.0	1.0	1.1	1.0	0.9	1.1	1.0	1.0	1.0	0.9	0.9
FLIN FLON	1.1	1.0	1.0	0.8	1.0	1.1	0.9	1.0	0.9	0.9	1.1	1.0	1.0	1.0	1.0	1.0	1.0	1.1	0.9	0.8	1.0	1.0	1.0	1.0	0.8	1.0
GILBERT PLAINS	0.6	1.1	0.9	1.0	0.9	0.6	0.6	0.6	0.9	1.0	1.0	0.9	0.7	0.8	0.9	0.9	0.8	0.8	0.9	0.8	1.1	0.9	0.9	0.8	0.7	0.6
GILLAM	0.8	1.1	1.0	1.2	0.9	1.1	0.9	0.7	1.0	0.9	1.0	0.9	1.0	0.9	1.0	0.8	0.8	0.9	0.8	0.7	0.9	0.9	1.2	1.2	1.1	1.0
GIMLI	1.0	1.1						0.8																		
GIMLI INDUSTRIAL PARK			0.9	1.0	0.8	1.0	1.0		1.0	1.1	0.8	0.9	1.0	0.9	1.1	1.0	0.9	1.0	0.9	0.9	1.0	1.0	1.0	1.1	0.8	0.8
GLADSTONE	0.6	1.0	0.6	0.5	0.7	0.9	0.6	0.6	0.6	0.5	0.4	0.7	0.6	0.9	0.8	0.6	0.7	0.8	1.0	0.6	0.7	0.8	0.8	0.9	0.7	0.9
GRISWOLD SIOUX VALLEY BAND	0.8								1.0	1.2	0.6	1.3	1.0	0.8	0.9		1.0	0.9	1.0	0.8	0.9	0.8	0.7	0.9	0.7	
HAMIOTA	1.1	1.1	0.9	1.0	0.9	1.0	0.8	1.0	1.2	1.1	1.2	0.8	1.2	1.2	1.3	1.2	1.2	1.2	1.2		1.3	1.2	1.3	1.3	1.2	1.2
HARTNEY	0.5	1.1	0.8	0.9	0.9	0.9	0.8	0.8	0.9	0.6	0.8	0.8	0.7	0.9	1.1	1.0	0.9	0.9	0.7	0.7	0.7	0.8	0.9	0.9	0.9	0.9
KILLARNEY	0.9	1.1	0.8	0.9	0.9	1.0	0.9	0.9	0.5	1.1	0.8	1.0	1.1	1.1	0.8	1.0	0.9	1.1	0.8	0.9	1.1	1.1	0.9	1.0	0.9	0.8
LETELLIER-RRRWTP	0.9	1.1	1.0	1.0	0.9	1.0	1.0	1.1	1.1	1.2	1.0	1.0	1.0	1.0	1.0	1.0	0.9	1.0	0.9	0.9	1.1	1.0	1.1	1.1	1.0	1.0
LONG PLAIN	0.6	1.1	0.7	0.8	0.6	1.8	0.9	0.7	0.9	0.9	0.7	0.8	0.9	0.9	0.9	0.5	0.5	0.5	0.9	0.6	1.0	0.8	0.9	0.8	0.7	0.7
MANITOU	1.1	0.9	1.0	1.1	1.0	1.1	1.1	1.0	1.1	1.1	0.9	0.9	1.0	0.9	1.0	1.1	0.8	1.1	1.0	0.9	1.0	1.1	1.1	1.1	1.0	1.0
MELITA	0.7	1.0	0.8	1.0	1.0	1.0	0.8	0.8	0.6	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.8	1.0	0.9	1.0	0.9	0.8	0.8
MINNEDOSA	0.5	1.0		0.8	0.8	0.8	0.8	0.8	0.9	0.8	0.8	0.9	0.8	0.8	0.9	0.8	0.8	0.9	0.8	0.7	0.9	0.9	1.2	0.9	0.8	0.8
MORDEN	0.5	1.1	0.9	0.9	0.9	1.1	0.9	0.9	0.9	1.1	0.8	0.8	0.8	0.8	0.9	0.8	0.9	1.0	1.0	0.8	1.0	1.0	1.1	1.3	0.9	0.8
MORRIS	0.8	1.0	0.9	1.0	0.9	1.1	0.8	1.1	1.1	1.1	1.1	1.3	1.1	1.1	1.1	0.9	0.9	1.1	0.9	0.9	0.9	0.9	1.0	0.9	1.0	1.0

Manitoba Health Fluoride Monitoring Program

Table 3

Fluoride Control Data Laboratory Results - 2005 / 2006 - Summary

The figures in this table reflect results of the testing of bi-weekly composite samples for fluoride concentration in parts per million

Location / Period Number	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
NEEPAWA	0.7	1.1	1.0	1.0	0.8	0.8	0.7	1.1	0.8	0.8	0.8	1.4	0.7	0.7	0.7	0.8	0.7	0.7	0.8	0.6	0.6	0.6	0.4	0.2	0.5	0.7
NORWAY HOUSE COMMUNITY COUNCIL		1.1	1.1	1.2	1.3	1.8	2.4			1.6	1.0		1.3	0.9	1.3	0.9	1.1	1.0								
PILOT MOUND	0.9	1.1	0.7	0.9	0.8	0.8	0.8	0.6	0.8	0.6	0.9	0.8	0.7	0.9	0.9	0.2	0.8	0.9	0.8	0.7	0.8	0.8	0.9	0.8	0.6	0.8
PINAWA	1.0	1.0	0.9	1.0	1.2	1.1	0.8	0.9	1.1	0.9	1.0	1.2	1.2	1.2	0.9	1.1	1.1	1.0	1.0	0.9	1.0	0.9	1.3	1.4	0.7	0.4
PORTAGE LA PRAIRIE	0.8	0.7	0.9	1.0	0.9	1.1	0.9	0.8	0.9	1.1	1.0	0.9	1.0	0.8	1.0	0.8	0.9	1.1	1.0	0.8	0.8	0.9	0.9	0.9	1.0	0.8
RESTON	1.0	1.1	1.0	1.5	1.4	1.0	1.0	0.8	0.7	1.0	1.2	1.1	0.9	0.9	0.8	1.0	1.0	1.1	0.8	0.9	1.2	1.2	1.2	1.0	1.1	1.2
RIVERS	1.1	1.0	0.8	1.0	1.4	1.0	0.8	0.9	0.9	0.8	0.8	0.9	0.9	1.0	0.9	0.8	0.9	1.1	1.1	0.8	1.0	1.0	1.0	1.1	1.0	1.0
ROBLIN	0.9	1.0	0.8	1.0	0.9	1.0	0.9	0.9	0.9	0.9	1.0	0.9	1.0	1.0	1.0	0.9	0.9	1.0	0.9	0.8	0.9	0.9	0.9	0.9	0.9	0.9
ROSSBURN	1.0	1.0		0.7	0.9	0.9	0.9	0.9	1.0	0.9	0.9	0.8	0.8	0.7	0.8	1.1	0.7	0.7	0.8	0.8	0.9	0.9	0.9	0.8	0.8	0.8
RUSSELL	1.0	1.1	1.0	1.0	1.0	1.1	1.0	1.0	1.0	1.0	1.1	1.1	1.1	1.1	1.1	0.9	0.9	1.0	1.0	0.9	1.0	1.0	1.0	1.1	0.8	0.9
SANFORD (RM MACDONALD)	0.7	1.1	0.8	0.9	1.0	1.1	0.8	0.9	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.9	0.9	1.1	1.0	0.9	1.1	1.0	1.0	0.9	0.9	1.1
SAPOTAWEYAK	0.7	0.6	0.8	0.6	0.6	0.6	0.6	0.7	0.9	1.0	0.7	0.7	0.7	0.7	0.8	0.6	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.6	0.6
SHILO	0.9	1.0	1.0	1.0	0.9	1.0	0.8	0.8	0.9	1.0	1.1	1.0	1.0	1.1	1.1	1.0	0.9	1.0	0.9	0.9	1.1	1.2		1.0	0.9	1.0
SOMERSET	0.7	1.0	0.9	1.3	0.6	0.4	0.5	0.8	0.6	0.6	0.7	0.6	0.6	0.6	0.9	1.0	0.5	0.6	0.8	0.8	0.9	0.9	0.9	0.9	0.7	0.7
SOURIS	0.8	1.1	0.9	1.0	0.9	0.9	0.8	0.8	0.9	0.9		1.1	0.8	0.9	1.0	0.7	0.7	1.1	0.8	0.9	1.0	1.1	0.9	1.4	0.9	0.6
STEINBACH	1.0	1.0	0.9	0.9	0.9	0.9	0.9	0.9	0.9	1.1	0.9	1.1	1.0	1.0	1.0	1.0	0.9	0.9	0.5	0.4	0.5	0.7	0.7	0.6	0.7	0.7
STEPHENFIELD	0.9	1.1	1.1	1.2	1.1	1.1	1.0	1.2	1.2	1.1	1.1	1.1	1.1	1.1	1.1	0.6	0.8	0.9	0.9	0.9	1.0	1.0	1.2	1.2	1.1	1.0
SWAN RIVER	0.9	1.0	1.0	1.0	1.0	0.9	0.9	0.9	0.9	1.1	0.9	1.0	1.0	0.9	1.0	0.9	0.9	1.1	1.0	1.0	1.0	1.1	1.1	1.1	1.0	1.0
THE PAS	0.6	1.1	0.9	0.9	0.9	1.0	0.9	0.9	0.9	0.9	0.9	1.0	1.0	1.0	1.0	0.9	0.9	1.1	1.0	0.9	1.0	1.0	1.1	1.0	1.0	1.0
TREHERNE	0.9	1.1	0.9	0.9	0.8	0.8	0.8	0.8	0.9	0.7	0.9	0.9	0.7	0.9	1.0	1.0	0.9	1.0	1.0	0.8	1.0	1.0	1.0	0.9	1.0	1.0
VIRDEN	1.0	1.1	1.2	1.0	1.1	1.0	0.7	0.7	1.1	0.8	0.5	0.5	0.9	1.0	1.0	0.9	1.1	1.2	1.1	1.0	0.9	0.9	1.0	0.9	0.8	1.0
WABOWDEN	1.3	1.2	1.3	1.2	1.1	0.7	1.6	1.0	0.9	0.9	1.6	1.1	1.0	0.9	1.0	1.0	1.0	1.0	0.9	0.8	0.9	0.9	1.0	1.1	1.3	1.1
WINKLER	0.8	1.1	0.9	0.8	0.8	1.0	0.8	0.8	0.9	0.9	0.8	0.9	1.0	1.0	1.0	0.9	0.8	1.0	0.9	0.8	1.0	0.9	0.8	0.9	0.8	1.0
WINNIPEG	0.9	1.1	0.9	0.9	0.8	0.8	0.9	0.8	0.9	1.0	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.9	0.9	0.8	0.9	0.9	0.9	0.9	0.9	0.9
WINNIPEGOSIS	0.9	1.0	0.9	0.9	0.6	0.6	0.6	0.6	0.6	1.1	1.0	1.1	1.0	1.0	1.0	1.2	0.8	1.0	0.9	0.7	0.9	0.9	1.0	0.9	0.8	0.9

FLUORIDATION CONTROL DATA - KEY

All figures reported are recorded in parts per million (ppm) or milligrams per litre (mg/L).

COMPOSITE (LAB)
Fluoride level analysis conducted by ALS Laboratory Group on the bi-weekly composite sample submitted by the water plant operator.

COMPOSITE (OPERATOR)
Fluoride level analysis conducted and reported by the water treatment plant operator on the bi-weekly sample before it is submitted to ALS Laboratory Group.

NOTE: If "NOT AVAILABLE" appears in any column, it indicates that data is not available due to one of the following reasons:

- sample not submitted
- sample broken in transit
- information not provided
- sample was contaminated

Fluoride Control Data 2005 / 2006

LOCATION	AUSTIN	FLUORIDATOR	LMI A151
OPERATOR	Ed Sattler	CHEMICAL	Na2SiF6 (Dry)
PHONE	637-2101	NATURAL FLUORIDE	0.19

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.0	1.00
2	APR 2 - APR 15	1.1	0.90
3	APR 16 - APR 29	0.9	1.00
4	APR 30 - MAY 13	0.9	1.06
5	MAY 14 - MAY 27	0.7	0.83
6	MAY 28 - JUN 10	0.9	1.00
7	JUN 11 - JUN 24	0.9	0.88
8	JUN 25 - JUL 8	1.0	0.93
9	JUL 9 - JUL 22	1.0	0.90
10	JUL 23 - AUG 5	1.0	1.17
11	AUG 6 - AUG 19	1.1	1.21
12	AUG 20 - SEP 2	1.1	0.95
13	SEP 3 - SEP 16	1.0	1.00
14	SEP 17 - SEP 30	1.0	0.91
15	OCT 1 - OCT 14	1.0	1.00
16	OCT 15 - OCT 28	1.1	1.12
17	OCT 29 - NOV 11	1.0	1.11
18	NOV 12 - NOV 25	1.1	1.02
19	NOV 26 - DEC 9	1.0	0.86
20	DEC 10 - DEC 23	0.9	1.00
21	DEC 24 - JAN 6	1.2	NOT AVAILABLE
22	JAN 7 - JAN 20	1.3	1.20
23	JAN 21 - FEB 3	1.5	1.21
24	FEB 4 - FEB 17	1.5	1.31
25	FEB 18 - MAR 3	1.0	1.13
26	MAR 4 - MAR 17	1.1	1.12

Summary for AUSTIN		
Average	1.1	1.03
Minimum	0.7	0.83
Maximum	1.5	1.31
Samples Above Limit	3	
Samples Below Limits	1	
% Outside Limits:	15%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	BALDUR	FLUORIDATOR	LMI A151
OPERATOR	Raymond Lussier	CHEMICAL	NaF 4 %
PHONE	535-2047	NATURAL FLUORIDE	0.22

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.8	0.87
2	APR 2 - APR 15	1.1	0.85
3	APR 16 - APR 29	0.9	0.96
4	APR 30 - MAY 13	1.0	0.91
5	MAY 14 - MAY 27	0.9	0.95
6	MAY 28 - JUN 10	0.8	0.88
7	JUN 11 - JUN 24	0.9	0.94
8	JUN 25 - JUL 8	1.0	0.90
9	JUL 9 - JUL 22	1.0	0.91
10	JUL 23 - AUG 5	1.1	0.93
11	AUG 6 - AUG 19	0.9	0.87
12	AUG 20 - SEP 2	0.9	0.90
13	SEP 3 - SEP 16	0.9	0.92
14	SEP 17 - SEP 30	0.9	0.94
15	OCT 1 - OCT 14	0.9	0.87
16	OCT 15 - OCT 28	0.9	0.92
17	OCT 29 - NOV 11	0.9	1.00
18	NOV 12 - NOV 25	1.1	0.96
19	NOV 26 - DEC 9	0.9	0.94
20	DEC 10 - DEC 23	0.8	0.89
21	DEC 24 - JAN 6	0.9	0.89
22	JAN 7 - JAN 20	0.9	0.86
23	JAN 21 - FEB 3	1.0	0.90
24	FEB 4 - FEB 17	0.9	0.95
25	FEB 18 - MAR 3	0.8	0.87
26	MAR 4 - MAR 17	0.8	0.88

Summary for BALDUR		
Average	0.9	0.91
Minimum	0.8	0.85
Maximum	1.1	1.00
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION BENITO
OPERATOR Rick Kinaschuk
PHONE 539-2229

FLUORIDATOR LMI A151
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.3

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.8	1.00
2	APR 2 - APR 15	1.0	1.00
3	APR 16 - APR 29	1.0	1.00
4	APR 30 - MAY 13	1.0	1.00
5	MAY 14 - MAY 27	1.0	NOT AVAILABLE
6	MAY 28 - JUN 10	1.0	1.00
7	JUN 11 - JUN 24	0.9	1.00
8	JUN 25 - JUL 8	0.9	1.00
9	JUL 9 - JUL 22	1.0	1.00
10	JUL 23 - AUG 5	0.9	1.00
11	AUG 6 - AUG 19	1.0	1.00
12	AUG 20 - SEP 2	1.0	1.00
13	SEP 3 - SEP 16	1.0	1.00
14	SEP 17 - SEP 30	0.9	0.90
15	OCT 1 - OCT 14	0.9	0.90
16	OCT 15 - OCT 28	0.7	0.80
17	OCT 29 - NOV 11	0.7	0.90
18	NOV 12 - NOV 25	0.9	0.90
19	NOV 26 - DEC 9	0.9	0.90
20	DEC 10 - DEC 23	0.8	0.90
21	DEC 24 - JAN 6	0.9	1.00
22	JAN 7 - JAN 20	1.0	0.90
23	JAN 21 - FEB 3	1.0	0.90
24	FEB 4 - FEB 17	0.9	NOT AVAILABLE
25	FEB 18 - MAR 3	0.8	1.00
26	MAR 4 - MAR 17	0.8	0.90

Summary for BENITO

Average	0.9	0.95
Minimum	0.7	0.80
Maximum	1.0	1.00
Samples Above Limit	0	
Samples Below Limits	2	
% Outside Limits:	8%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	BINSCARTH	FLUORIDATOR	Prom Gamma
OPERATOR	Steve Stewart	CHEMICAL	H2SiF6 25 %
PHONE	532-2165	NATURAL FLUORIDE	0.24

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	NOT AVAILABLE	NOT AVAILABLE
2	APR 2 - APR 15	0.7	NOT AVAILABLE
3	APR 16 - APR 29	0.7	0.98
4	APR 30 - MAY 13	0.7	0.92
5	MAY 14 - MAY 27	0.8	1.06
6	MAY 28 - JUN 10	1.1	1.10
7	JUN 11 - JUN 24	0.8	1.02
8	JUN 25 - JUL 8	0.7	1.05
9	JUL 9 - JUL 22	0.7	0.93
10	JUL 23 - AUG 5	0.6	1.04
11	AUG 6 - AUG 19	0.7	0.94
12	AUG 20 - SEP 2	0.7	1.06
13	SEP 3 - SEP 16	0.7	1.00
14	SEP 17 - SEP 30	0.8	0.86
15	OCT 1 - OCT 14	0.9	1.02
16	OCT 15 - OCT 28	0.8	1.14
17	OCT 29 - NOV 11	0.8	0.84
18	NOV 12 - NOV 25	0.9	1.09
19	NOV 26 - DEC 9	0.8	1.16
20	DEC 10 - DEC 23	0.9	1.06
21	DEC 24 - JAN 6	0.9	1.00
22	JAN 7 - JAN 20	0.9	1.12
23	JAN 21 - FEB 3	1.0	0.91
24	FEB 4 - FEB 17	0.9	1.04
25	FEB 18 - MAR 3	0.8	1.07
26	MAR 4 - MAR 17	0.8	1.14

Summary for BINSCARTH		
Average	0.8	1.02
Minimum	0.6	0.84
Maximum	1.1	1.16
Samples Above Limit	0	
Samples Below Limits	9	
% Outside Limits:	36%	
Number of Samples	25	

Fluoride Control Data 2005 / 2006

LOCATION	BIRTLE	FLUORIDATOR	LMI A741
OPERATOR	Darwin Fleury	CHEMICAL	NaF 4 %
PHONE	842-5311	NATURAL FLUORIDE	0.26

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.2	1.48
2	APR 2 - APR 15	1.1	1.57
3	APR 16 - APR 29	1.0	1.48
4	APR 30 - MAY 13	1.0	1.43
5	MAY 14 - MAY 27	1.0	1.42
6	MAY 28 - JUN 10	0.5	NOT AVAILABLE
7	JUN 11 - JUN 24	1.8	1.45
8	JUN 25 - JUL 8	1.2	1.59
9	JUL 9 - JUL 22	1.2	1.68
10	JUL 23 - AUG 5	1.1	1.61
11	AUG 6 - AUG 19	1.3	1.75
12	AUG 20 - SEP 2	0.5	1.29
13	SEP 3 - SEP 16	0.8	1.48
14	SEP 17 - SEP 30	1.2	1.38
15	OCT 1 - OCT 14	1.2	1.43
16	OCT 15 - OCT 28	1.1	1.39
17	OCT 29 - NOV 11	1.0	1.61
18	NOV 12 - NOV 25	1.1	1.19
19	NOV 26 - DEC 9	0.6	1.16
20	DEC 10 - DEC 23	0.3	0.77
21	DEC 24 - JAN 6	0.3	0.98
22	JAN 7 - JAN 20	0.3	0.90
23	JAN 21 - FEB 3	0.3	NOT AVAILABLE
24	FEB 4 - FEB 17	0.2	0.80
25	FEB 18 - MAR 3	0.2	0.90
26	MAR 4 - MAR 17	0.3	0.80

Summary for BIRTLE		
Average	0.8	1.31
Minimum	0.2	0.77
Maximum	1.8	1.75
Samples Above Limit	2	
Samples Below Limits	10	
% Outside Limits:	46%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	BOISSEVAIN	FLUORIDATOR	Precision
OPERATOR	Barry Chinner	CHEMICAL	NaF 4 %
PHONE	534-6762	NATURAL FLUORIDE	0.2

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	1.16
2	APR 2 - APR 15	0.8	1.18
3	APR 16 - APR 29	0.9	1.13
4	APR 30 - MAY 13	1.1	1.32
5	MAY 14 - MAY 27	0.9	1.26
6	MAY 28 - JUN 10	0.9	1.17
7	JUN 11 - JUN 24	0.9	1.27
8	JUN 25 - JUL 8	0.9	1.18
9	JUL 9 - JUL 22	0.9	1.47
10	JUL 23 - AUG 5	1.0	1.26
11	AUG 6 - AUG 19	0.9	1.28
12	AUG 20 - SEP 2	1.0	1.32
13	SEP 3 - SEP 16	1.0	1.26
14	SEP 17 - SEP 30	1.0	1.12
15	OCT 1 - OCT 14	1.0	1.10
16	OCT 15 - OCT 28	0.9	1.22
17	OCT 29 - NOV 11	0.9	1.29
18	NOV 12 - NOV 25	1.1	1.21
19	NOV 26 - DEC 9	0.9	1.22
20	DEC 10 - DEC 23	0.8	1.25
21	DEC 24 - JAN 6	1.0	1.28
22	JAN 7 - JAN 20	1.0	1.28
23	JAN 21 - FEB 3	1.0	1.21
24	FEB 4 - FEB 17	1.0	1.28
25	FEB 18 - MAR 3	0.9	1.30
26	MAR 4 - MAR 17	0.9	1.23

Summary for BOISSEVAIN		
Average	0.9	1.24
Minimum	0.8	1.10
Maximum	1.1	1.47
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	BRANDON	FLUORIDATOR	W&T A690
OPERATOR	Brad McIntosh	CHEMICAL	Na2SiF6 (Dry)
PHONE	729-2274	NATURAL FLUORIDE	0.2

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.1	1.30
2	APR 2 - APR 15	1.0	1.16
3	APR 16 - APR 29	0.8	0.86
4	APR 30 - MAY 13	0.8	1.14
5	MAY 14 - MAY 27	0.8	1.04
6	MAY 28 - JUN 10	0.8	1.20
7	JUN 11 - JUN 24	0.8	1.14
8	JUN 25 - JUL 8	0.8	1.07
9	JUL 9 - JUL 22	0.9	1.07
10	JUL 23 - AUG 5	0.8	1.10
11	AUG 6 - AUG 19	1.0	1.28
12	AUG 20 - SEP 2	0.9	1.26
13	SEP 3 - SEP 16	0.9	1.15
14	SEP 17 - SEP 30	0.9	1.20
15	OCT 1 - OCT 14	0.8	1.08
16	OCT 15 - OCT 28	0.8	1.03
17	OCT 29 - NOV 11	0.9	1.14
18	NOV 12 - NOV 25	0.8	1.03
19	NOV 26 - DEC 9	0.7	0.98
20	DEC 10 - DEC 23	0.7	0.90
21	DEC 24 - JAN 6	0.8	0.92
22	JAN 7 - JAN 20	0.8	1.02
23	JAN 21 - FEB 3	0.8	0.82
24	FEB 4 - FEB 17	0.8	1.14
25	FEB 18 - MAR 3	0.7	0.99
26	MAR 4 - MAR 17	0.7	1.10

Summary for BRANDON		
Average	0.8	1.08
Minimum	0.7	0.82
Maximum	1.1	1.30
Samples Above Limit	0	
Samples Below Limits	4	
% Outside Limits:	15%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	CARMAN	FLUORIDATOR	W&T 47-050
OPERATOR	Replaced	CHEMICAL	H2SiF6 25 %
PHONE	745-2481	NATURAL FLUORIDE	0.21

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.7	0.97
2	APR 2 - APR 15	1.1	0.79
3	APR 16 - APR 29	0.7	0.92
4	APR 30 - MAY 13	0.9	1.04
5	MAY 14 - MAY 27	0.7	0.98
6	MAY 28 - JUN 10	0.7	0.91
7	JUN 11 - JUN 24	0.7	0.90
8	JUN 25 - JUL 8	0.8	1.08
9	JUL 9 - JUL 22	0.9	1.01
10	JUL 23 - AUG 5	0.7	0.98
11	AUG 6 - AUG 19	0.8	0.90
12	AUG 20 - SEP 2	0.8	1.06
13	SEP 3 - SEP 16	0.9	1.12
14	SEP 17 - SEP 30	0.9	1.01
15	OCT 1 - OCT 14	1.0	0.96
16	OCT 15 - OCT 28	0.8	NOT AVAILABLE
17	OCT 29 - NOV 11	0.7	0.94
18	NOV 12 - NOV 25	0.7	1.07
19	NOV 26 - DEC 9	0.6	NOT AVAILABLE
20	DEC 10 - DEC 23	0.6	1.16
21	DEC 24 - JAN 6	0.7	0.90
22	JAN 7 - JAN 20	0.7	0.90
23	JAN 21 - FEB 3	0.8	1.00
24	FEB 4 - FEB 17	0.8	0.86
25	FEB 18 - MAR 3	0.7	0.80
26	MAR 4 - MAR 17	0.8	0.89

Summary for CARMAN		
Average	0.8	0.96
Minimum	0.6	0.79
Maximum	1.1	1.16
Samples Above Limit	0	
Samples Below Limits	13	
% Outside Limits:	50%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	CARTIER REGIONAL	FLUORIDATOR	N/A
OPERATOR	Dave Pirt	CHEMICAL	H2SiF6 25 %
PHONE	N/A	NATURAL FLUORIDE	0

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.1	1.30
2	APR 2 - APR 15	1.2	1.30
3	APR 16 - APR 29	NOT AVAILABLE	NOT AVAILABLE
4	APR 30 - MAY 13	1.1	1.40
5	MAY 14 - MAY 27	1.3	1.30
6	MAY 28 - JUN 10	1.1	1.30
7	JUN 11 - JUN 24	1.2	1.40
8	JUN 25 - JUL 8	1.2	1.40
9	JUL 9 - JUL 22	1.2	1.40
10	JUL 23 - AUG 5	1.2	1.30
11	AUG 6 - AUG 19	1.1	1.30
12	AUG 20 - SEP 2	1.2	1.40
13	SEP 3 - SEP 16	1.0	1.20
14	SEP 17 - SEP 30	1.0	1.20
15	OCT 1 - OCT 14	1.0	1.10
16	OCT 15 - OCT 28	1.0	0.90
17	OCT 29 - NOV 11	1.0	1.10
18	NOV 12 - NOV 25	1.1	0.90
19	NOV 26 - DEC 9	0.9	1.20
20	DEC 10 - DEC 23	0.8	1.10
21	DEC 24 - JAN 6	1.0	1.00
22	JAN 7 - JAN 20	0.9	1.20
23	JAN 21 - FEB 3	0.9	1.00
24	FEB 4 - FEB 17	0.8	1.00
25	FEB 18 - MAR 3	0.8	1.00
26	MAR 4 - MAR 17	0.9	1.10

Summary for CARTIER REGIONAL		
Average	1.0	1.19
Minimum	0.8	0.90
Maximum	1.3	1.40
Samples Above Limit	1	
Samples Below Limits	0	
% Outside Limits:	4%	
Number of Samples	25	

Fluoride Control Data 2005 / 2006

LOCATION CHURCHILL
OPERATOR William Ayotte
PHONE 675-8871

FLUORIDATOR Prom Gamma
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE < 0.10

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	0.90
2	APR 2 - APR 15	1.1	1.00
3	APR 16 - APR 29	1.0	1.00
4	APR 30 - MAY 13	1.1	1.10
5	MAY 14 - MAY 27	1.0	1.00
6	MAY 28 - JUN 10	1.1	1.00
7	JUN 11 - JUN 24	1.1	NOT AVAILABLE
8	JUN 25 - JUL 8	1.0	0.90
9	JUL 9 - JUL 22	1.1	NOT AVAILABLE
10	JUL 23 - AUG 5	1.1	1.00
11	AUG 6 - AUG 19	1.1	1.20
12	AUG 20 - SEP 2	1.1	NOT AVAILABLE
13	SEP 3 - SEP 16	1.0	1.00
14	SEP 17 - SEP 30	1.0	0.80
15	OCT 1 - OCT 14	1.1	1.00
16	OCT 15 - OCT 28	0.9	0.90
17	OCT 29 - NOV 11	0.9	1.00
18	NOV 12 - NOV 25	1.1	1.00
19	NOV 26 - DEC 9	0.9	0.90
20	DEC 10 - DEC 23	0.9	0.90
21	DEC 24 - JAN 6	1.1	1.00
22	JAN 7 - JAN 20	1.2	NOT AVAILABLE
23	JAN 21 - FEB 3	1.0	NOT AVAILABLE
24	FEB 4 - FEB 17	1.0	1.10
25	FEB 18 - MAR 3	0.9	1.10
26	MAR 4 - MAR 17	0.9	NOT AVAILABLE

Summary for CHURCHILL

Average	1.0	0.99
Minimum	0.9	0.80
Maximum	1.2	1.20
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	CRANBERRY PORTAGE	FLUORIDATOR	LMI A151
OPERATOR	Darcy Rajczakowski	CHEMICAL	NaF 4 %
PHONE	472-3621	NATURAL FLUORIDE	< 0.10

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	NOT AVAILABLE
2	APR 2 - APR 15	1.1	1.00
3	APR 16 - APR 29	1.0	NOT AVAILABLE
4	APR 30 - MAY 13	1.2	1.25
5	MAY 14 - MAY 27	1.0	NOT AVAILABLE
6	MAY 28 - JUN 10	1.0	1.17
7	JUN 11 - JUN 24	1.2	NOT AVAILABLE
8	JUN 25 - JUL 8	1.1	1.25
9	JUL 9 - JUL 22	1.0	0.95
10	JUL 23 - AUG 5	1.0	NOT AVAILABLE
11	AUG 6 - AUG 19	1.0	NOT AVAILABLE
12	AUG 20 - SEP 2	1.1	NOT AVAILABLE
13	SEP 3 - SEP 16	1.1	NOT AVAILABLE
14	SEP 17 - SEP 30	1.2	NOT AVAILABLE
15	OCT 1 - OCT 14	1.2	NOT AVAILABLE
16	OCT 15 - OCT 28	1.0	NOT AVAILABLE
17	OCT 29 - NOV 11	1.0	NOT AVAILABLE
18	NOV 12 - NOV 25	1.1	NOT AVAILABLE
19	NOV 26 - DEC 9	1.0	NOT AVAILABLE
20	DEC 10 - DEC 23	0.9	NOT AVAILABLE
21	DEC 24 - JAN 6	1.1	NOT AVAILABLE
22	JAN 7 - JAN 20	1.1	NOT AVAILABLE
23	JAN 21 - FEB 3	1.1	NOT AVAILABLE
24	FEB 4 - FEB 17	0.9	NOT AVAILABLE
25	FEB 18 - MAR 3	1.0	NOT AVAILABLE
26	MAR 4 - MAR 17	1.1	NOT AVAILABLE

Summary for CRANBERRY PORTAGE		
Average	1.1	1.12
Minimum	0.9	0.95
Maximum	1.2	1.25
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	CROSS LAKE RESERVE	FLUORIDATOR	LMI Saturator
OPERATOR	Lawrence McLeod	CHEMICAL	NaF 4 %
PHONE	676-2044	NATURAL FLUORIDE	< 0.10

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.1	0.90
2	APR 2 - APR 15	1.0	1.30
3	APR 16 - APR 29	1.0	1.00
4	APR 30 - MAY 13	1.2	1.00
5	MAY 14 - MAY 27	1.1	1.20
6	MAY 28 - JUN 10	1.1	1.10
7	JUN 11 - JUN 24	0.8	1.00
8	JUN 25 - JUL 8	1.0	0.80
9	JUL 9 - JUL 22	1.1	1.00
10	JUL 23 - AUG 5	1.0	1.00
11	AUG 6 - AUG 19	1.2	1.10
12	AUG 20 - SEP 2	1.1	1.00
13	SEP 3 - SEP 16	1.1	1.00
14	SEP 17 - SEP 30	1.2	1.10
15	OCT 1 - OCT 14	1.1	1.00
16	OCT 15 - OCT 28	0.9	1.00
17	OCT 29 - NOV 11	0.9	1.00
18	NOV 12 - NOV 25	NOT AVAILABLE	NOT AVAILABLE
19	NOV 26 - DEC 9	1.1	1.00
20	DEC 10 - DEC 23	0.9	1.10
21	DEC 24 - JAN 6	1.1	1.00
22	JAN 7 - JAN 20	1.1	1.00
23	JAN 21 - FEB 3	1.4	1.20
24	FEB 4 - FEB 17	1.3	1.20
25	FEB 18 - MAR 3	1.1	1.10
26	MAR 4 - MAR 17	1.0	1.00

Summary for CROSS LAKE RESERVE		
Average	1.1	1.04
Minimum	0.8	0.80
Maximum	1.4	1.30
Samples Above Limit	2	
Samples Below Limits	0	
% Outside Limits:	8%	
Number of Samples	25	

Fluoride Control Data 2005 / 2006

LOCATION DAUPHIN
OPERATOR Bill Brenner
PHONE 638-3690

FLUORIDATOR W&T A690 Pa
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE 0.14

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	0.97
2	APR 2 - APR 15	0.7	0.95
3	APR 16 - APR 29	0.2	0.99
4	APR 30 - MAY 13	1.1	0.96
5	MAY 14 - MAY 27	0.9	0.98
6	MAY 28 - JUN 10	0.9	0.96
7	JUN 11 - JUN 24	0.9	0.97
8	JUN 25 - JUL 8	0.9	1.07
9	JUL 9 - JUL 22	0.9	0.94
10	JUL 23 - AUG 5	0.9	1.02
11	AUG 6 - AUG 19	0.9	0.98
12	AUG 20 - SEP 2	0.9	1.04
13	SEP 3 - SEP 16	1.0	1.07
14	SEP 17 - SEP 30	1.0	1.01
15	OCT 1 - OCT 14	0.9	1.04
16	OCT 15 - OCT 28	0.9	0.91
17	OCT 29 - NOV 11	0.8	1.02
18	NOV 12 - NOV 25	0.8	1.06
19	NOV 26 - DEC 9	0.8	1.02
20	DEC 10 - DEC 23	0.8	1.00
21	DEC 24 - JAN 6	1.1	1.20
22	JAN 7 - JAN 20	1.0	NOT AVAILABLE
23	JAN 21 - FEB 3	1.0	1.10
24	FEB 4 - FEB 17	1.0	NOT AVAILABLE
25	FEB 18 - MAR 3	1.0	1.19
26	MAR 4 - MAR 17	0.8	1.00

Summary for DAUPHIN

Average	0.9	1.02
Minimum	0.2	0.91
Maximum	1.1	1.20
Samples Above Limit	0	
Samples Below Limits	2	
% Outside Limits:	8%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION DELORAINE
OPERATOR Kent Corkish
PHONE 747-2062

FLUORIDATOR LMI Saturator
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.16

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	1.13
2	APR 2 - APR 15	1.1	1.14
3	APR 16 - APR 29	1.0	1.17
4	APR 30 - MAY 13	1.0	1.23
5	MAY 14 - MAY 27	0.9	1.16
6	MAY 28 - JUN 10	0.9	1.13
7	JUN 11 - JUN 24	0.9	1.27
8	JUN 25 - JUL 8	0.9	1.18
9	JUL 9 - JUL 22	0.9	1.11
10	JUL 23 - AUG 5	0.9	1.18
11	AUG 6 - AUG 19	0.9	1.07
12	AUG 20 - SEP 2	1.1	1.18
13	SEP 3 - SEP 16	1.1	1.19
14	SEP 17 - SEP 30	1.0	1.16
15	OCT 1 - OCT 14	1.1	1.11
16	OCT 15 - OCT 28	1.0	1.17
17	OCT 29 - NOV 11	1.0	1.08
18	NOV 12 - NOV 25	1.1	1.14
19	NOV 26 - DEC 9	1.0	1.12
20	DEC 10 - DEC 23	0.9	1.11
21	DEC 24 - JAN 6	1.1	1.07
22	JAN 7 - JAN 20	1.0	1.17
23	JAN 21 - FEB 3	1.0	1.09
24	FEB 4 - FEB 17	1.0	1.07
25	FEB 18 - MAR 3	0.9	1.18
26	MAR 4 - MAR 17	0.9	1.13

Summary for DELORAINE

Average	1.0	1.14
Minimum	0.9	1.07
Maximum	1.1	1.27
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION FLIN FLON
OPERATOR Kevin Komarnicki
PHONE 687-9772

FLUORIDATOR Prominent
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE < 0.10

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.1	0.91
2	APR 2 - APR 15	1.0	0.98
3	APR 16 - APR 29	1.0	1.02
4	APR 30 - MAY 13	0.8	0.89
5	MAY 14 - MAY 27	1.0	1.03
6	MAY 28 - JUN 10	1.1	1.05
7	JUN 11 - JUN 24	0.9	0.93
8	JUN 25 - JUL 8	1.0	1.01
9	JUL 9 - JUL 22	0.9	NOT AVAILABLE
10	JUL 23 - AUG 5	0.9	1.04
11	AUG 6 - AUG 19	1.1	1.06
12	AUG 20 - SEP 2	1.0	1.05
13	SEP 3 - SEP 16	1.0	1.08
14	SEP 17 - SEP 30	1.0	0.93
15	OCT 1 - OCT 14	1.0	1.17
16	OCT 15 - OCT 28	1.0	1.25
17	OCT 29 - NOV 11	1.0	1.15
18	NOV 12 - NOV 25	1.1	1.19
19	NOV 26 - DEC 9	0.9	1.26
20	DEC 10 - DEC 23	0.8	1.10
21	DEC 24 - JAN 6	1.0	1.21
22	JAN 7 - JAN 20	1.0	1.13
23	JAN 21 - FEB 3	1.0	1.02
24	FEB 4 - FEB 17	1.0	0.96
25	FEB 18 - MAR 3	0.8	0.85
26	MAR 4 - MAR 17	1.0	0.90

Summary for FLIN FLON

Average	1.0	1.05
Minimum	0.8	0.85
Maximum	1.1	1.26
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	GILBERT PLAINS	FLUORIDATOR	LMI A741
OPERATOR	Lloyd Beckley	CHEMICAL	NaF 4 %
PHONE	548-2149	NATURAL FLUORIDE	0.19

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.6	0.96
2	APR 2 - APR 15	1.1	0.85
3	APR 16 - APR 29	0.9	1.00
4	APR 30 - MAY 13	1.0	1.00
5	MAY 14 - MAY 27	0.9	1.05
6	MAY 28 - JUN 10	0.6	0.95
7	JUN 11 - JUN 24	0.6	0.85
8	JUN 25 - JUL 8	0.6	0.80
9	JUL 9 - JUL 22	0.9	1.30
10	JUL 23 - AUG 5	1.0	1.10
11	AUG 6 - AUG 19	1.0	1.00
12	AUG 20 - SEP 2	0.9	1.00
13	SEP 3 - SEP 16	0.7	0.95
14	SEP 17 - SEP 30	0.8	0.98
15	OCT 1 - OCT 14	0.9	1.00
16	OCT 15 - OCT 28	0.9	1.05
17	OCT 29 - NOV 11	0.8	1.00
18	NOV 12 - NOV 25	0.8	0.85
19	NOV 26 - DEC 9	0.9	1.05
20	DEC 10 - DEC 23	0.8	1.10
21	DEC 24 - JAN 6	1.1	1.10
22	JAN 7 - JAN 20	0.9	1.00
23	JAN 21 - FEB 3	0.9	1.00
24	FEB 4 - FEB 17	0.8	0.80
25	FEB 18 - MAR 3	0.7	0.85
26	MAR 4 - MAR 17	0.6	0.70

Summary for GILBERT PLAINS		
Average	0.8	0.97
Minimum	0.6	0.70
Maximum	1.1	1.30
Samples Above Limit	0	
Samples Below Limits	7	
% Outside Limits:	27%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	GILLAM	FLUORIDATOR	W&T
OPERATOR	John McDonald	CHEMICAL	H2SiF6 25 %
PHONE	652-2377	NATURAL FLUORIDE	< 0.10

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.8	1.09
2	APR 2 - APR 15	1.1	0.72
3	APR 16 - APR 29	1.0	0.70
4	APR 30 - MAY 13	1.2	1.82
5	MAY 14 - MAY 27	0.9	1.17
6	MAY 28 - JUN 10	1.1	1.61
7	JUN 11 - JUN 24	0.9	0.84
8	JUN 25 - JUL 8	0.7	1.21
9	JUL 9 - JUL 22	1.0	0.91
10	JUL 23 - AUG 5	0.9	1.13
11	AUG 6 - AUG 19	1.0	1.57
12	AUG 20 - SEP 2	0.9	1.31
13	SEP 3 - SEP 16	1.0	1.56
14	SEP 17 - SEP 30	0.9	1.13
15	OCT 1 - OCT 14	1.0	0.91
16	OCT 15 - OCT 28	0.8	0.75
17	OCT 29 - NOV 11	0.8	1.33
18	NOV 12 - NOV 25	0.9	1.38
19	NOV 26 - DEC 9	0.8	1.49
20	DEC 10 - DEC 23	0.7	0.99
21	DEC 24 - JAN 6	0.9	0.85
22	JAN 7 - JAN 20	0.9	2.01
23	JAN 21 - FEB 3	1.2	2.06
24	FEB 4 - FEB 17	1.2	1.56
25	FEB 18 - MAR 3	1.1	1.59
26	MAR 4 - MAR 17	1.0	1.21

Summary for GILLAM		
Average	1.0	1.27
Minimum	0.7	0.70
Maximum	1.2	2.06
Samples Above Limit	0	
Samples Below Limits	2	
% Outside Limits:	8%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION GIMLI
OPERATOR Greg Elson
PHONE 642-7443

FLUORIDATOR Myers
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.45

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.0	1.08
2	APR 2 - APR 15	1.1	0.90
3	APR 16 - APR 29	NOT AVAILABLE	NOT AVAILABLE
4	APR 30 - MAY 13	NOT AVAILABLE	NOT AVAILABLE
5	MAY 14 - MAY 27	NOT AVAILABLE	NOT AVAILABLE
6	MAY 28 - JUN 10	NOT AVAILABLE	NOT AVAILABLE
7	JUN 11 - JUN 24	NOT AVAILABLE	NOT AVAILABLE
8	JUN 25 - JUL 8	0.8	0.90
9	JUL 9 - JUL 22	NOT AVAILABLE	NOT AVAILABLE
10	JUL 23 - AUG 5	NOT AVAILABLE	NOT AVAILABLE
11	AUG 6 - AUG 19	NOT AVAILABLE	NOT AVAILABLE
12	AUG 20 - SEP 2	NOT AVAILABLE	NOT AVAILABLE
13	SEP 3 - SEP 16	NOT AVAILABLE	NOT AVAILABLE
14	SEP 17 - SEP 30	NOT AVAILABLE	NOT AVAILABLE
15	OCT 1 - OCT 14	NOT AVAILABLE	NOT AVAILABLE
16	OCT 15 - OCT 28	NOT AVAILABLE	NOT AVAILABLE
17	OCT 29 - NOV 11	NOT AVAILABLE	NOT AVAILABLE
18	NOV 12 - NOV 25	NOT AVAILABLE	NOT AVAILABLE
19	NOV 26 - DEC 9	NOT AVAILABLE	NOT AVAILABLE
20	DEC 10 - DEC 23	NOT AVAILABLE	NOT AVAILABLE
21	DEC 24 - JAN 6	NOT AVAILABLE	NOT AVAILABLE
22	JAN 7 - JAN 20	NOT AVAILABLE	NOT AVAILABLE
23	JAN 21 - FEB 3	NOT AVAILABLE	NOT AVAILABLE
24	FEB 4 - FEB 17	NOT AVAILABLE	NOT AVAILABLE
25	FEB 18 - MAR 3	NOT AVAILABLE	NOT AVAILABLE
26	MAR 4 - MAR 17	NOT AVAILABLE	NOT AVAILABLE

Summary for GIMLI

Average	1.0	0.96
Minimum	0.8	0.90
Maximum	1.1	1.08
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	3	

Fluoride Control Data 2005 / 2006

LOCATION	GIMLI INDUSTRIAL PARK	FLUORIDATOR	W&T A747
OPERATOR	Richard Bezdietny	CHEMICAL	NaF 4 %
PHONE	642-5297	NATURAL FLUORIDE	0.43

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	NOT AVAILABLE	NOT AVAILABLE
2	APR 2 - APR 15	NOT AVAILABLE	NOT AVAILABLE
3	APR 16 - APR 29	0.9	1.00
4	APR 30 - MAY 13	1.0	0.86
5	MAY 14 - MAY 27	0.8	0.94
6	MAY 28 - JUN 10	1.0	1.02
7	JUN 11 - JUN 24	1.0	1.13
8	JUN 25 - JUL 8	NOT AVAILABLE	NOT AVAILABLE
9	JUL 9 - JUL 22	1.0	1.00
10	JUL 23 - AUG 5	1.1	0.95
11	AUG 6 - AUG 19	0.8	0.90
12	AUG 20 - SEP 2	0.9	1.10
13	SEP 3 - SEP 16	1.0	1.06
14	SEP 17 - SEP 30	0.9	0.96
15	OCT 1 - OCT 14	1.1	1.05
16	OCT 15 - OCT 28	1.0	1.10
17	OCT 29 - NOV 11	0.9	1.10
18	NOV 12 - NOV 25	1.0	1.02
19	NOV 26 - DEC 9	0.9	1.08
20	DEC 10 - DEC 23	0.9	1.07
21	DEC 24 - JAN 6	1.0	1.03
22	JAN 7 - JAN 20	1.0	1.00
23	JAN 21 - FEB 3	1.0	1.00
24	FEB 4 - FEB 17	1.1	1.10
25	FEB 18 - MAR 3	0.8	1.00
26	MAR 4 - MAR 17	0.8	0.86

Summary for GIMLI INDUSTRIAL PARK		
Average	1.0	1.01
Minimum	0.8	0.86
Maximum	1.1	1.13
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	23	

Fluoride Control Data 2005 / 2006

LOCATION	GLADSTONE	FLUORIDATOR	W&T A745
OPERATOR	Glen Emerson	CHEMICAL	Na2SiF6 (Dry)
PHONE	385-2917	NATURAL FLUORIDE	0.22

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.6	1.04
2	APR 2 - APR 15	1.0	1.00
3	APR 16 - APR 29	0.6	1.11
4	APR 30 - MAY 13	0.5	0.72
5	MAY 14 - MAY 27	0.7	1.21
6	MAY 28 - JUN 10	0.9	1.18
7	JUN 11 - JUN 24	0.6	0.94
8	JUN 25 - JUL 8	0.6	0.85
9	JUL 9 - JUL 22	0.6	1.02
10	JUL 23 - AUG 5	0.5	1.01
11	AUG 6 - AUG 19	0.4	0.77
12	AUG 20 - SEP 2	0.7	1.09
13	SEP 3 - SEP 16	0.6	0.95
14	SEP 17 - SEP 30	0.9	1.29
15	OCT 1 - OCT 14	0.8	1.17
16	OCT 15 - OCT 28	0.6	0.98
17	OCT 29 - NOV 11	0.7	0.85
18	NOV 12 - NOV 25	0.8	1.04
19	NOV 26 - DEC 9	1.0	1.49
20	DEC 10 - DEC 23	0.6	0.93
21	DEC 24 - JAN 6	0.7	1.12
22	JAN 7 - JAN 20	0.8	0.98
23	JAN 21 - FEB 3	0.8	0.97
24	FEB 4 - FEB 17	0.9	1.05
25	FEB 18 - MAR 3	0.7	1.02
26	MAR 4 - MAR 17	0.9	1.02

Summary for GLADSTONE		
Average	0.7	1.03
Minimum	0.4	0.72
Maximum	1.0	1.49
Samples Above Limit	0	
Samples Below Limits	16	
% Outside Limits:	62%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	GRISWOLD SIOUX VALLEY BAND	FLUORIDATOR	N/A
OPERATOR	Avin Dowan	CHEMICAL	NaF 4 %
PHONE	855-2690	NATURAL FLUORIDE	0.1

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.8	NOT AVAILABLE
2	APR 2 - APR 15	NOT AVAILABLE	NOT AVAILABLE
3	APR 16 - APR 29	NOT AVAILABLE	NOT AVAILABLE
4	APR 30 - MAY 13	NOT AVAILABLE	NOT AVAILABLE
5	MAY 14 - MAY 27	NOT AVAILABLE	NOT AVAILABLE
6	MAY 28 - JUN 10	NOT AVAILABLE	NOT AVAILABLE
7	JUN 11 - JUN 24	NOT AVAILABLE	NOT AVAILABLE
8	JUN 25 - JUL 8	NOT AVAILABLE	NOT AVAILABLE
9	JUL 9 - JUL 22	1.0	NOT AVAILABLE
10	JUL 23 - AUG 5	1.2	NOT AVAILABLE
11	AUG 6 - AUG 19	0.6	NOT AVAILABLE
12	AUG 20 - SEP 2	1.3	NOT AVAILABLE
13	SEP 3 - SEP 16	1.0	NOT AVAILABLE
14	SEP 17 - SEP 30	0.8	NOT AVAILABLE
15	OCT 1 - OCT 14	0.9	NOT AVAILABLE
16	OCT 15 - OCT 28	NOT AVAILABLE	NOT AVAILABLE
17	OCT 29 - NOV 11	1.0	NOT AVAILABLE
18	NOV 12 - NOV 25	0.9	NOT AVAILABLE
19	NOV 26 - DEC 9	1.0	NOT AVAILABLE
20	DEC 10 - DEC 23	0.8	NOT AVAILABLE
21	DEC 24 - JAN 6	0.9	NOT AVAILABLE
22	JAN 7 - JAN 20	0.8	NOT AVAILABLE
23	JAN 21 - FEB 3	0.7	NOT AVAILABLE
24	FEB 4 - FEB 17	0.9	NOT AVAILABLE
25	FEB 18 - MAR 3	0.7	NOT AVAILABLE
26	MAR 4 - MAR 17	NOT AVAILABLE	NOT AVAILABLE

Summary for GRISWOLD SIOUX VALLEY BAND

Average	0.9
Minimum	0.6
Maximum	1.3
Samples Above Limit	1
Samples Below Limits	3
% Outside Limits:	24%
Number of Samples	17

Fluoride Control Data 2005 / 2006

LOCATION	HAMIOTA	FLUORIDATOR	LMI A751
OPERATOR	Ken Curle	CHEMICAL	NaF 4 %
PHONE	764-2531	NATURAL FLUORIDE	0.29

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.1	NOT AVAILABLE
2	APR 2 - APR 15	1.1	0.84
3	APR 16 - APR 29	0.9	0.82
4	APR 30 - MAY 13	1.0	0.80
5	MAY 14 - MAY 27	0.9	0.88
6	MAY 28 - JUN 10	1.0	0.92
7	JUN 11 - JUN 24	0.8	0.89
8	JUN 25 - JUL 8	1.0	0.99
9	JUL 9 - JUL 22	1.2	0.94
10	JUL 23 - AUG 5	1.1	NOT AVAILABLE
11	AUG 6 - AUG 19	1.2	1.08
12	AUG 20 - SEP 2	0.8	0.66
13	SEP 3 - SEP 16	1.2	1.12
14	SEP 17 - SEP 30	1.2	1.10
15	OCT 1 - OCT 14	1.3	1.10
16	OCT 15 - OCT 28	1.2	1.07
17	OCT 29 - NOV 11	1.2	1.21
18	NOV 12 - NOV 25	1.2	1.31
19	NOV 26 - DEC 9	1.2	1.29
20	DEC 10 - DEC 23	NOT AVAILABLE	NOT AVAILABLE
21	DEC 24 - JAN 6	1.3	1.14
22	JAN 7 - JAN 20	1.2	0.96
23	JAN 21 - FEB 3	1.3	1.16
24	FEB 4 - FEB 17	1.3	1.18
25	FEB 18 - MAR 3	1.2	0.89
26	MAR 4 - MAR 17	1.2	1.12

Summary for HAMIOTA		
Average	1.1	1.02
Minimum	0.8	0.66
Maximum	1.3	1.31
Samples Above Limit	4	
Samples Below Limits	0	
% Outside Limits:	16%	
Number of Samples	25	

Fluoride Control Data 2005 / 2006

LOCATION	HARTNEY	FLUORIDATOR	LMI A741
OPERATOR	Greg Morrison	CHEMICAL	NaF 4 %
PHONE	858-2076	NATURAL FLUORIDE	0.2

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.5	0.80
2	APR 2 - APR 15	1.1	0.90
3	APR 16 - APR 29	0.8	0.90
4	APR 30 - MAY 13	0.9	1.00
5	MAY 14 - MAY 27	0.9	0.95
6	MAY 28 - JUN 10	0.9	0.95
7	JUN 11 - JUN 24	0.8	0.90
8	JUN 25 - JUL 8	0.8	0.90
9	JUL 9 - JUL 22	0.9	0.90
10	JUL 23 - AUG 5	0.6	0.80
11	AUG 6 - AUG 19	0.8	0.90
12	AUG 20 - SEP 2	0.8	0.90
13	SEP 3 - SEP 16	0.7	0.80
14	SEP 17 - SEP 30	0.9	0.95
15	OCT 1 - OCT 14	1.1	1.00
16	OCT 15 - OCT 28	1.0	1.00
17	OCT 29 - NOV 11	0.9	1.00
18	NOV 12 - NOV 25	0.9	1.05
19	NOV 26 - DEC 9	0.7	0.95
20	DEC 10 - DEC 23	0.7	0.90
21	DEC 24 - JAN 6	0.7	0.85
22	JAN 7 - JAN 20	0.8	0.90
23	JAN 21 - FEB 3	0.9	0.95
24	FEB 4 - FEB 17	0.9	1.00
25	FEB 18 - MAR 3	0.9	0.95
26	MAR 4 - MAR 17	0.9	NOT AVAILABLE

Summary for HARTNEY		
Average	0.8	0.92
Minimum	0.5	0.80
Maximum	1.1	1.05
Samples Above Limit	0	
Samples Below Limits	6	
% Outside Limits:	23%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	KILLARNEY	FLUORIDATOR	LMI B721
OPERATOR	Shawn Lamb	CHEMICAL	NaF 4 %
PHONE	523-8944	NATURAL FLUORIDE	0.19

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	1.31
2	APR 2 - APR 15	1.1	1.35
3	APR 16 - APR 29	0.8	1.21
4	APR 30 - MAY 13	0.9	1.33
5	MAY 14 - MAY 27	0.9	1.42
6	MAY 28 - JUN 10	1.0	1.42
7	JUN 11 - JUN 24	0.9	1.50
8	JUN 25 - JUL 8	0.9	1.55
9	JUL 9 - JUL 22	0.5	0.96
10	JUL 23 - AUG 5	1.1	1.43
11	AUG 6 - AUG 19	0.8	1.38
12	AUG 20 - SEP 2	1.0	1.56
13	SEP 3 - SEP 16	1.1	1.59
14	SEP 17 - SEP 30	1.1	1.69
15	OCT 1 - OCT 14	0.8	1.49
16	OCT 15 - OCT 28	1.0	1.47
17	OCT 2 - NOV 11	0.9	1.52
18	NOV 12 - NOV 25	1.1	1.55
19	NOV 26 - DEC 9	0.8	1.27
20	DEC 10 - DEC 23	0.9	1.55
21	DEC 24 - JAN 6	1.1	1.62
22	JAN 7 - JAN 20	1.1	1.58
23	JAN 21 - FEB 3	0.9	1.56
24	FEB 4 - FEB 17	1.0	1.65
25	FEB 18 - MAR 3	0.9	1.52
26	MAR 4 - MAR 17	0.8	1.52

Summary for KILLARNEY		
Average	0.9	1.46
Minimum	0.5	0.96
Maximum	1.1	1.69
Samples Above Limit	0	
Samples Below Limits	1	
% Outside Limits:	4%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	LETELLIER-RRRWTP	FLUORIDATOR	LMI
OPERATOR	Kurt Henry	CHEMICAL	H2SiF6 25 %
PHONE	737-2265	NATURAL FLUORIDE	0.17

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	1.17
2	APR 2 - APR 15	1.1	1.10
3	APR 16 - APR 29	1.0	1.10
4	APR 30 - MAY 13	1.0	1.11
5	MAY 14 - MAY 27	0.9	0.92
6	MAY 28 - JUN 10	1.0	1.00
7	JUN 11 - JUN 24	1.0	1.11
8	JUN 25 - JUL 8	1.1	1.16
9	JUL 9 - JUL 22	1.1	1.11
10	JUL 23 - AUG 5	1.2	1.15
11	AUG 6 - AUG 19	1.0	1.10
12	AUG 20 - SEP 2	1.0	1.06
13	SEP 3 - SEP 16	1.0	1.00
14	SEP 17 - SEP 30	1.0	1.09
15	OCT 1 - OCT 14	1.0	0.98
16	OCT 15 - OCT 28	1.0	1.12
17	OCT 29 - NOV 11	0.9	1.15
18	NOV 12 - NOV 25	1.0	1.08
19	NOV 26 - DEC 9	0.9	1.01
20	DEC 10 - DEC 23	0.9	1.00
21	DEC 24 - JAN 6	1.1	1.10
22	JAN 7 - JAN 20	1.0	1.09
23	JAN 21 - FEB 3	1.1	1.15
24	FEB 4 - FEB 17	1.1	1.12
25	FEB 18 - MAR 3	1.0	1.03
26	MAR 4 - MAR 17	1.0	1.07

Summary for LETELLIER-RRRWTP		
Average	1.0	1.08
Minimum	0.9	0.92
Maximum	1.2	1.17
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	LONG PLAIN	FLUORIDATOR	LMI Saturator
OPERATOR	Morris Peters	CHEMICAL	NaF 4 %
PHONE	252-2094	NATURAL FLUORIDE	0.23

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.6	NOT AVAILABLE
2	APR 2 - APR 15	1.1	1.02
3	APR 16 - APR 29	0.7	0.67
4	APR 30 - MAY 13	0.8	0.82
5	MAY 14 - MAY 27	0.6	0.51
6	MAY 28 - JUN 10	1.8	1.49
7	JUN 11 - JUN 24	0.9	0.88
8	JUN 25 - JUL 8	0.7	0.62
9	JUL 9 - JUL 22	0.9	0.99
10	JUL 23 - AUG 5	0.9	0.84
11	AUG 6 - AUG 19	0.7	0.63
12	AUG 20 - SEP 2	0.8	0.66
13	SEP 3 - SEP 16	0.9	NOT AVAILABLE
14	SEP 17 - SEP 30	0.9	NOT AVAILABLE
15	OCT 1 - OCT 14	0.9	0.93
16	OCT 15 - OCT 28	0.5	0.43
17	OCT 29 - NOV 11	0.5	0.76
18	NOV 12 - NOV 25	0.5	0.82
19	NOV 26 - DEC 9	0.9	0.83
20	DEC 10 - DEC 23	0.6	NOT AVAILABLE
21	DEC 24 - JAN 6	1.0	NOT AVAILABLE
22	JAN 7 - JAN 20	0.8	0.98
23	JAN 21 - FEB 3	0.9	1.43
24	FEB 4 - FEB 17	0.8	1.10
25	FEB 18 - MAR 3	0.7	0.95
26	MAR 4 - MAR 17	0.7	1.01

Summary for LONG PLAIN		
Average	0.8	0.87
Minimum	0.5	0.43
Maximum	1.8	1.49
Samples Above Limit	1	
Samples Below Limits	11	
% Outside Limits:	46%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	MANITOU	FLUORIDATOR	LMI Saturator
OPERATOR	Bob Barett	CHEMICAL	NaF 4 %
PHONE	242-2885	NATURAL FLUORIDE	0.19

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.1	1.19
2	APR 2 - APR 15	0.9	1.17
3	APR 16 - APR 29	1.0	1.11
4	APR 30 - MAY 13	1.1	1.00
5	MAY 14 - MAY 27	1.0	1.15
6	MAY 28 - JUN 10	1.1	1.03
7	JUN 11 - JUN 24	1.1	1.25
8	JUN 25 - JUL 8	1.0	1.19
9	JUL 9 - JUL 22	1.1	1.15
10	JUL 23 - AUG 5	1.1	1.18
11	AUG 6 - AUG 19	0.9	1.05
12	AUG 20 - SEP 2	0.9	1.03
13	SEP 3 - SEP 16	1.0	1.12
14	SEP 17 - SEP 30	0.9	1.10
15	OCT 1 - OCT 14	1.0	1.05
16	OCT 15 - OCT 28	1.1	1.19
17	OCT 29 - NOV 11	0.8	1.08
18	NOV 12 - NOV 25	1.1	1.12
19	NOV 26 - DEC 9	1.0	1.17
20	DEC 10 - DEC 23	0.9	1.13
21	DEC 24 - JAN 6	1.0	1.07
22	JAN 7 - JAN 20	1.1	1.18
23	JAN 21 - FEB 3	1.1	1.20
24	FEB 4 - FEB 17	1.1	1.14
25	FEB 18 - MAR 3	1.0	1.19
26	MAR 4 - MAR 17	1.0	1.18

Summary for MANITOU		
Average	1.0	1.13
Minimum	0.8	1.00
Maximum	1.1	1.25
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	MELITA	FLUORIDATOR	W&T Saturato
OPERATOR	Bob Reddaway	CHEMICAL	NaF 4 %
PHONE	522-3413	NATURAL FLUORIDE	0.18

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.7	1.03
2	APR 2 - APR 15	1.0	1.02
3	APR 16 - APR 29	0.8	1.01
4	APR 30 - MAY 13	1.0	1.42
5	MAY 14 - MAY 27	1.0	1.18
6	MAY 28 - JUN 10	1.0	1.30
7	JUN 11 - JUN 24	0.8	1.18
8	JUN 25 - JUL 8	0.8	0.96
9	JUL 9 - JUL 22	0.6	1.05
10	JUL 23 - AUG 5	0.7	1.02
11	AUG 6 - AUG 19	0.8	1.02
12	AUG 20 - SEP 2	0.8	0.98
13	SEP 3 - SEP 16	0.8	1.05
14	SEP 17 - SEP 30	0.8	1.01
15	OCT 1 - OCT 14	0.8	0.95
16	OCT 15 - OCT 28	0.8	0.85
17	OCT 29 - NOV 11	0.8	1.16
18	NOV 12 - NOV 25	0.9	0.97
19	NOV 26 - DEC 9	0.9	0.94
20	DEC 10 - DEC 23	0.8	1.10
21	DEC 24 - JAN 6	1.0	0.97
22	JAN 7 - JAN 20	0.9	1.10
23	JAN 21 - FEB 3	1.0	0.91
24	FEB 4 - FEB 17	0.9	1.03
25	FEB 18 - MAR 3	0.8	1.19
26	MAR 4 - MAR 17	0.8	1.21

Summary for MELITA		
Average	0.8	1.06
Minimum	0.6	0.85
Maximum	1.0	1.42
Samples Above Limit	0	
Samples Below Limits	3	
% Outside Limits:	12%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	MINNEDOSA	FLUORIDATOR	Prominent
OPERATOR	Frank Taylor	CHEMICAL	H2SiF6 25 %
PHONE	867-2949	NATURAL FLUORIDE	0.28

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.5	1.02
2	APR 2 - APR 15	1.0	1.05
3	APR 16 - APR 29	NOT AVAILABLE	NOT AVAILABLE
4	APR 30 - MAY 13	0.8	1.05
5	MAY 14 - MAY 27	0.8	1.03
6	MAY 28 - JUN 10	0.8	1.15
7	JUN 11 - JUN 24	0.8	1.05
8	JUN 25 - JUL 8	0.8	1.05
9	JUL 9 - JUL 22	0.9	1.05
10	JUL 23 - AUG 5	0.8	1.10
11	AUG 6 - AUG 19	0.8	1.10
12	AUG 20 - SEP 2	0.9	1.05
13	SEP 3 - SEP 16	0.8	1.05
14	SEP 17 - SEP 30	0.8	1.05
15	OCT 1 - OCT 14	0.9	1.15
16	OCT 15 - OCT 28	0.8	NOT AVAILABLE
17	OCT 29 - NOV 11	0.8	1.15
18	NOV 12 - NOV 25	0.9	1.10
19	NOV 26 - DEC 9	0.8	1.15
20	DEC 10 - DEC 23	0.7	1.05
21	DEC 24 - JAN 6	0.9	1.15
22	JAN 7 - JAN 20	0.9	1.15
23	JAN 21 - FEB 3	1.2	1.15
24	FEB 4 - FEB 17	0.9	1.15
25	FEB 18 - MAR 3	0.8	1.15
26	MAR 4 - MAR 17	0.8	1.15

Summary for MINNEDOSA

Average	0.8	1.10
Minimum	0.5	1.02
Maximum	1.2	1.15
Samples Above Limit	0	
Samples Below Limits	2	
% Outside Limits:	8%	
Number of Samples	25	

Fluoride Control Data 2005 / 2006

LOCATION	MORDEN	FLUORIDATOR	Prominent
OPERATOR	Retired	CHEMICAL	H2SiF6 25 %
PHONE	822-5707	NATURAL FLUORIDE	0.32

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.5	1.20
2	APR 2 - APR 15	1.1	1.10
3	APR 16 - APR 29	0.9	1.00
4	APR 30 - MAY 13	0.9	1.20
5	MAY 14 - MAY 27	0.9	1.10
6	MAY 28 - JUN 10	1.1	1.00
7	JUN 11 - JUN 24	0.9	1.40
8	JUN 25 - JUL 8	0.9	1.30
9	JUL 9 - JUL 22	0.9	1.20
10	JUL 23 - AUG 5	1.1	1.13
11	AUG 6 - AUG 19	0.8	1.20
12	AUG 20 - SEP 2	0.8	1.20
13	SEP 3 - SEP 16	0.8	1.06
14	SEP 17 - SEP 30	0.8	0.99
15	OCT 1 - OCT 14	0.9	1.21
16	OCT 15 - OCT 28	0.8	1.00
17	OCT 29 - NOV 11	0.9	1.10
18	NOV 12 - NOV 25	1.0	1.03
19	NOV 26 - DEC 9	1.0	1.26
20	DEC 10 - DEC 23	0.8	1.21
21	DEC 24 - JAN 6	1.0	1.46
22	JAN 7 - JAN 20	1.0	1.29
23	JAN 21 - FEB 3	1.1	0.80
24	FEB 4 - FEB 17	1.3	1.30
25	FEB 18 - MAR 3	0.9	1.33
26	MAR 4 - MAR 17	0.8	1.20

Summary for MORDEN		
Average	0.9	1.16
Minimum	0.5	0.80
Maximum	1.3	1.46
Samples Above Limit	1	
Samples Below Limits	1	
% Outside Limits:	8%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	MORRIS	FLUORIDATOR	Prominent
OPERATOR	Richard Dupuis	CHEMICAL	H2SiF6 25 %
PHONE	746-2790	NATURAL FLUORIDE	0.22

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.8	1.08
2	APR 2 - APR 15	1.0	1.01
3	APR 16 - APR 29	0.9	1.06
4	APR 30 - MAY 13	1.0	1.07
5	MAY 14 - MAY 27	0.9	NOT AVAILABLE
6	MAY 28 - JUN 10	1.1	0.98
7	JUN 11 - JUN 24	0.8	0.86
8	JUN 25 - JUL 8	1.1	1.08
9	JUL 9 - JUL 22	1.1	1.26
10	JUL 23 - AUG 5	1.1	1.01
11	AUG 6 - AUG 19	1.1	1.17
12	AUG 20 - SEP 2	1.3	1.21
13	SEP 3 - SEP 16	1.1	1.24
14	SEP 17 - SEP 30	1.1	1.00
15	OCT 1 - OCT 14	1.1	1.03
16	OCT 15 - OCT 28	0.9	0.93
17	OCT 29 - NOV 11	0.9	1.01
18	NOV 12 - NOV 25	1.1	1.09
19	NOV 26 - DEC 9	0.9	1.04
20	DEC 10 - DEC 23	0.9	1.02
21	DEC 24 - JAN 6	0.9	1.17
22	JAN 7 - JAN 20	0.9	0.99
23	JAN 21 - FEB 3	1.0	1.06
24	FEB 4 - FEB 17	0.9	1.22
25	FEB 18 - MAR 3	1.0	1.06
26	MAR 4 - MAR 17	1.0	1.06

Summary for MORRIS		
Average	1.0	1.07
Minimum	0.8	0.86
Maximum	1.3	1.26
Samples Above Limit	1	
Samples Below Limits	0	
% Outside Limits:	4%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	NEEPAWA	FLUORIDATOR	W&T A690
OPERATOR	Dan Wagner	CHEMICAL	Na2SiF6 (Dry)
PHONE	476-5331	NATURAL FLUORIDE	0.24

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.7	0.90
2	APR 2 - APR 15	1.1	1.13
3	APR 16 - APR 29	1.0	1.32
4	APR 30 - MAY 13	1.0	1.04
5	MAY 14 - MAY 27	0.8	0.84
6	MAY 28 - JUN 10	0.8	0.83
7	JUN 11 - JUN 24	0.7	1.08
8	JUN 25 - JUL 8	1.1	1.21
9	JUL 9 - JUL 22	0.8	1.11
10	JUL 23 - AUG 5	0.8	1.23
11	AUG 6 - AUG 19	0.8	1.42
12	AUG 20 - SEP 2	1.4	0.98
13	SEP 3 - SEP 16	0.7	1.18
14	SEP 17 - SEP 30	0.7	0.91
15	OCT 1 - OCT 14	0.7	0.98
16	OCT 15 - OCT 28	0.8	1.29
17	OCT 29 - NOV 11	0.7	0.93
18	NOV 12 - NOV 25	0.7	0.92
19	NOV 26 - DEC 9	0.8	1.00
20	DEC 10 - DEC 23	0.6	0.92
21	DEC 24 - JAN 6	0.6	0.86
22	JAN 7 - JAN 20	0.6	0.84
23	JAN 21 - FEB 3	0.4	0.85
24	FEB 4 - FEB 17	0.2	0.64
25	FEB 18 - MAR 3	0.5	0.81
26	MAR 4 - MAR 17	0.7	0.94

Summary for NEEPAWA		
Average	0.8	1.01
Minimum	0.2	0.64
Maximum	1.4	1.42
Samples Above Limit	1	
Samples Below Limits	14	
% Outside Limits:	58%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION NORWAY HOUSE COMMUNITY COUNCIL FLUORIDATOR Prominent

OPERATOR Steve Mowatt CHEMICAL H2SiF6 25 %

PHONE 359-6719 NATURAL FLUORIDE 0.21

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	NOT AVAILABLE	NOT AVAILABLE
2	APR 2 - APR 15	1.1	NOT AVAILABLE
3	APR 16 - APR 29	1.1	1.15
4	APR 30 - MAY 13	1.2	0.23
5	MAY 14 - MAY 27	1.3	0.21
6	MAY 28 - JUN 10	1.8	0.72
7	JUN 11 - JUN 24	2.4	0.93
8	JUN 25 - JUL 8	NOT AVAILABLE	NOT AVAILABLE
9	JUL 9 - JUL 22	NOT AVAILABLE	NOT AVAILABLE
10	JUL 23 - AUG 5	1.6	1.21
11	AUG 6 - AUG 19	1.0	0.90
12	AUG 20 - SEP 2	NOT AVAILABLE	NOT AVAILABLE
13	SEP 3 - SEP 16	1.3	1.25
14	SEP 17 - SEP 30	0.9	0.88
15	OCT 1 - OCT 14	1.3	1.20
16	OCT 15 - OCT 28	0.9	1.04
17	OCT 29 - NOV 11	1.1	0.95
18	NOV 12 - NOV 25	1.0	1.41
19	NOV 26 - DEC 9	NOT AVAILABLE	NOT AVAILABLE
20	DEC 10 - DEC 23	NOT AVAILABLE	NOT AVAILABLE
21	DEC 24 - JAN 6	NOT AVAILABLE	NOT AVAILABLE
22	JAN 7 - JAN 20	NOT AVAILABLE	NOT AVAILABLE
23	JAN 21 - FEB 3	NOT AVAILABLE	NOT AVAILABLE
24	FEB 4 - FEB 17	NOT AVAILABLE	NOT AVAILABLE
25	FEB 18 - MAR 3	NOT AVAILABLE	NOT AVAILABLE
26	MAR 4 - MAR 17	NOT AVAILABLE	NOT AVAILABLE

Summary for NORWAY HOUSE COMMUNITY COUNCIL

Average	1.3	0.93
Minimum	0.9	0.21
Maximum	2.4	1.41
Samples Above Limit	6	
Samples Below Limits	0	
% Outside Limits:	43%	
Number of Samples	14	

Fluoride Control Data 2005 / 2006

LOCATION	PILOT MOUND	FLUORIDATOR	LMI Saturator
OPERATOR	Ron Forbes	CHEMICAL	NaF 4 %
PHONE	825-2115	NATURAL FLUORIDE	0.21

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	1.06
2	APR 2 - APR 15	1.1	0.85
3	APR 16 - APR 29	0.7	0.85
4	APR 30 - MAY 13	0.9	0.84
5	MAY 14 - MAY 27	0.8	1.17
6	MAY 28 - JUN 10	0.8	1.03
7	JUN 11 - JUN 24	0.8	0.99
8	JUN 25 - JUL 8	0.6	0.86
9	JUL 9 - JUL 22	0.8	1.04
10	JUL 23 - AUG 5	0.6	0.89
11	AUG 6 - AUG 19	0.9	1.02
12	AUG 20 - SEP 2	0.8	0.96
13	SEP 3 - SEP 16	0.7	0.92
14	SEP 17 - SEP 30	0.9	1.11
15	OCT 1 - OCT 14	0.9	1.03
16	OCT 15 - OCT 28	0.2	1.06
17	OCT 29 - NOV 11	0.8	1.01
18	NOV 12 - NOV 25	0.9	1.22
19	NOV 26 - DEC 9	0.8	1.06
20	DEC 10 - DEC 23	0.7	1.11
21	DEC 24 - JAN 6	0.8	1.11
22	JAN 7 - JAN 20	0.8	1.14
23	JAN 21 - FEB 3	0.9	1.16
24	FEB 4 - FEB 17	0.8	1.12
25	FEB 18 - MAR 3	0.6	1.04
26	MAR 4 - MAR 17	0.8	1.12

Summary for PILOT MOUND		
Average	0.8	1.03
Minimum	0.2	0.84
Maximum	1.1	1.22
Samples Above Limit	0	
Samples Below Limits	7	
% Outside Limits:	27%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	PINAWA	FLUORIDATOR	Pulse Mate
OPERATOR	Ron McDowall	CHEMICAL	H2SiF6 25 %
PHONE	753-2542	NATURAL FLUORIDE	0.08

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.0	1.00
2	APR 2 - APR 15	1.0	0.98
3	APR 16 - APR 29	0.9	0.98
4	APR 30 - MAY 13	1.0	0.98
5	MAY 14 - MAY 27	1.2	0.98
6	MAY 28 - JUN 10	1.1	1.05
7	JUN 11 - JUN 24	0.8	0.88
8	JUN 25 - JUL 8	0.9	0.90
9	JUL 9 - JUL 22	1.1	0.98
10	JUL 23 - AUG 5	0.9	1.00
11	AUG 6 - AUG 19	1.0	0.98
12	AUG 20 - SEP 2	1.2	0.98
13	SEP 3 - SEP 16	1.2	1.04
14	SEP 17 - SEP 30	1.2	1.01
15	OCT 1 - OCT 14	0.9	0.94
16	OCT 15 - OCT 28	1.1	0.98
17	OCT 29 - NOV 11	1.1	0.98
18	NOV 12 - NOV 25	1.0	0.98
19	NOV 26 - DEC 9	1.0	1.08
20	DEC 10 - DEC 23	0.9	1.00
21	DEC 24 - JAN 6	1.0	0.96
22	JAN 7 - JAN 20	0.9	0.98
23	JAN 21 - FEB 3	1.3	0.98
24	FEB 4 - FEB 17	1.4	0.98
25	FEB 18 - MAR 3	0.7	0.96
26	MAR 4 - MAR 17	0.4	0.96

Summary for PINAWA

Average	1.0	0.98
Minimum	0.4	0.88
Maximum	1.4	1.08
Samples Above Limit	2	
Samples Below Limits	2	
% Outside Limits:	15%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	PORTAGE LA PRAIRIE	FLUORIDATOR	W&T A690
OPERATOR	Doug Campbell	CHEMICAL	H2SiF6 25 %
PHONE	239-8373	NATURAL FLUORIDE	0.2

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.8	1.02
2	APR 2 - APR 15	0.7	NOT AVAILABLE
3	APR 16 - APR 29	0.9	1.35
4	APR 30 - MAY 13	1.0	1.25
5	MAY 14 - MAY 27	0.9	1.19
6	MAY 28 - JUN 10	1.1	1.20
7	JUN 11 - JUN 24	0.9	1.07
8	JUN 25 - JUL 8	0.8	1.09
9	JUL 9 - JUL 22	0.9	1.16
10	JUL 23 - AUG 5	1.1	1.40
11	AUG 6 - AUG 19	1.0	1.26
12	AUG 20 - SEP 2	0.9	1.14
13	SEP 3 - SEP 16	1.0	1.15
14	SEP 17 - SEP 30	0.8	1.07
15	OCT 1 - OCT 14	1.0	1.23
16	OCT 15 - OCT 28	0.8	0.86
17	OCT 29 - NOV 11	0.9	1.15
18	NOV 12 - NOV 25	1.1	1.28
19	NOV 26 - DEC 9	1.0	1.14
20	DEC 10 - DEC 23	0.8	1.17
21	DEC 24 - JAN 6	0.8	1.18
22	JAN 7 - JAN 20	0.9	1.10
23	JAN 21 - FEB 3	0.9	1.27
24	FEB 4 - FEB 17	0.9	1.24
25	FEB 18 - MAR 3	1.0	1.35
26	MAR 4 - MAR 17	0.8	1.08

Summary for PORTAGE LA PRAIRIE		
Average	0.9	1.18
Minimum	0.7	0.86
Maximum	1.1	1.40
Samples Above Limit	0	
Samples Below Limits	1	
% Outside Limits:	4%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	RESTON	FLUORIDATOR	W&T A745
OPERATOR	Ken Moore	CHEMICAL	NaF 4 %
PHONE	877-3862	NATURAL FLUORIDE	0.13

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.0	1.00
2	APR 2 - APR 15	1.1	0.95
3	APR 16 - APR 29	1.0	1.00
4	APR 30 - MAY 13	1.5	1.05
5	MAY 14 - MAY 27	1.4	1.05
6	MAY 28 - JUN 10	1.0	1.10
7	JUN 11 - JUN 24	1.0	1.10
8	JUN 25 - JUL 8	0.8	1.00
9	JUL 9 - JUL 22	0.7	1.00
10	JUL 23 - AUG 5	1.0	1.00
11	AUG 6 - AUG 19	1.2	1.05
12	AUG 20 - SEP 2	1.1	1.05
13	SEP 3 - SEP 16	0.9	1.00
14	SEP 17 - SEP 30	0.9	0.95
15	OCT 1 - OCT 14	0.8	0.90
16	OCT 15 - OCT 28	1.0	1.05
17	OCT 29 - NOV 11	1.0	1.10
18	NOV 12 - NOV 25	1.1	1.05
19	NOV 26 - DEC 9	0.8	0.95
20	DEC 10 - DEC 23	0.9	1.05
21	DEC 24 - JAN 6	1.2	1.05
22	JAN 7 - JAN 20	1.2	1.05
23	JAN 21 - FEB 3	1.2	1.10
24	FEB 4 - FEB 17	1.0	1.00
25	FEB 18 - MAR 3	1.1	1.05
26	MAR 4 - MAR 17	1.2	1.10

Summary for RESTON		
Average	1.0	1.03
Minimum	0.7	0.90
Maximum	1.5	1.10
Samples Above Limit	2	
Samples Below Limits	1	
% Outside Limits:	12%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	RIVERS	FLUORIDATOR	LMI Saturator
OPERATOR	Randy King	CHEMICAL	NaF 4 %
PHONE	328-7480	NATURAL FLUORIDE	0.18

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.1	0.85
2	APR 2 - APR 15	1.0	1.05
3	APR 16 - APR 29	0.8	0.74
4	APR 30 - MAY 13	1.0	0.81
5	MAY 14 - MAY 27	1.4	1.50
6	MAY 28 - JUN 10	1.0	1.12
7	JUN 11 - JUN 24	0.8	0.96
8	JUN 25 - JUL 8	0.9	1.18
9	JUL 9 - JUL 22	0.9	1.14
10	JUL 23 - AUG 5	0.8	0.79
11	AUG 6 - AUG 19	0.8	0.81
12	AUG 20 - SEP 2	0.9	1.18
13	SEP 3 - SEP 16	0.9	1.06
14	SEP 17 - SEP 30	1.0	0.80
15	OCT 1 - OCT 14	0.9	1.08
16	OCT 15 - OCT 28	0.8	1.00
17	OCT 29 - NOV 11	0.9	1.19
18	NOV 12 - NOV 25	1.1	0.84
19	NOV 26 - DEC 9	1.1	1.29
20	DEC 10 - DEC 23	0.8	1.38
21	DEC 24 - JAN 6	1.0	0.95
22	JAN 7 - JAN 20	1.0	1.10
23	JAN 21 - FEB 3	1.0	1.29
24	FEB 4 - FEB 17	1.1	0.95
25	FEB 18 - MAR 3	1.0	1.20
26	MAR 4 - MAR 17	1.0	1.03

Summary for RIVERS		
Average	1.0	1.05
Minimum	0.8	0.74
Maximum	1.4	1.50
Samples Above Limit	1	
Samples Below Limits	0	
% Outside Limits:	4%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	ROBLIN	FLUORIDATOR	W&T A745
OPERATOR	Glen Reierson	CHEMICAL	NaF 4 %
PHONE	937-2377	NATURAL FLUORIDE	0.26

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	1.10
2	APR 2 - APR 15	1.0	1.15
3	APR 16 - APR 29	0.8	1.05
4	APR 30 - MAY 13	1.0	1.00
5	MAY 14 - MAY 27	0.9	1.05
6	MAY 28 - JUN 10	1.0	1.00
7	JUN 11 - JUN 24	0.9	1.10
8	JUN 25 - JUL 8	0.9	1.10
9	JUL 9 - JUL 22	0.9	1.10
10	JUL 23 - AUG 5	0.9	1.05
11	AUG 6 - AUG 19	1.0	0.70
12	AUG 20 - SEP 2	0.9	1.00
13	SEP 3 - SEP 16	1.0	1.10
14	SEP 17 - SEP 30	1.0	1.10
15	OCT 1 - OCT 14	1.0	1.10
16	OCT 15 - OCT 28	0.9	1.05
17	OCT 29 - NOV 11	0.9	1.10
18	NOV 12 - NOV 25	1.0	1.10
19	NOV 26 - DEC 9	0.9	1.05
20	DEC 10 - DEC 23	0.8	1.10
21	DEC 24 - JAN 6	0.9	1.10
22	JAN 7 - JAN 20	0.9	1.10
23	JAN 21 - FEB 3	0.9	1.00
24	FEB 4 - FEB 17	0.9	1.10
25	FEB 18 - MAR 3	0.9	1.05
26	MAR 4 - MAR 17	0.9	1.05

Summary for ROBLIN		
Average	0.9	1.06
Minimum	0.8	0.70
Maximum	1.0	1.15
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	ROSSBURN	FLUORIDATOR	W&T A745
OPERATOR	Nick Antoniw	CHEMICAL	NaF 4 %
PHONE	859-2273	NATURAL FLUORIDE	0.1

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.0	1.30
2	APR 2 - APR 15	1.0	NOT AVAILABLE
3	APR 16 - APR 29	NOT AVAILABLE	NOT AVAILABLE
4	APR 30 - MAY 13	0.7	1.20
5	MAY 14 - MAY 27	0.9	1.10
6	MAY 28 - JUN 10	0.9	1.20
7	JUN 11 - JUN 24	0.9	1.20
8	JUN 25 - JUL 8	0.9	0.90
9	JUL 9 - JUL 22	1.0	0.90
10	JUL 23 - AUG 5	0.9	NOT AVAILABLE
11	AUG 6 - AUG 19	0.9	0.80
12	AUG 20 - SEP 2	0.8	1.00
13	SEP 3 - SEP 16	0.8	1.00
14	SEP 17 - SEP 30	0.7	1.00
15	OCT 1 - OCT 14	0.8	0.90
16	OCT 15 - OCT 28	1.1	0.70
17	OCT 29 - NOV 11	0.7	0.90
18	NOV 12 - NOV 25	0.7	0.80
19	NOV 26 - DEC 9	0.8	0.80
20	DEC 10 - DEC 23	0.8	1.10
21	DEC 24 - JAN 6	0.9	1.00
22	JAN 7 - JAN 20	0.9	0.90
23	JAN 21 - FEB 3	0.9	0.90
24	FEB 4 - FEB 17	0.8	1.00
25	FEB 18 - MAR 3	0.8	0.90
26	MAR 4 - MAR 17	0.8	1.10

Summary for ROSSBURN		
Average	0.9	0.98
Minimum	0.7	0.70
Maximum	1.1	1.30
Samples Above Limit	0	
Samples Below Limits	4	
% Outside Limits:	16%	
Number of Samples	25	

Fluoride Control Data 2005 / 2006

LOCATION	RUSSELL	FLUORIDATOR	LMI A151
OPERATOR	Mark Moan	CHEMICAL	NaF 4 %
PHONE	773-3185	NATURAL FLUORIDE	0.21

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.0	1.05
2	APR 2 - APR 15	1.1	0.97
3	APR 16 - APR 29	1.0	1.00
4	APR 30 - MAY 13	1.0	1.07
5	MAY 14 - MAY 27	1.0	1.03
6	MAY 28 - JUN 10	1.1	1.01
7	JUN 11 - JUN 24	1.0	1.15
8	JUN 25 - JUL 8	1.0	1.03
9	JUL 9 - JUL 22	1.0	1.09
10	JUL 23 - AUG 5	1.0	1.10
11	AUG 6 - AUG 19	1.1	1.00
12	AUG 20 - SEP 2	1.1	1.09
13	SEP 3 - SEP 16	1.1	1.04
14	SEP 17 - SEP 30	1.1	1.05
15	OCT 1 - OCT 14	1.1	1.06
16	OCT 15 - OCT 28	0.9	1.14
17	OCT 29 - NOV 11	0.9	1.07
18	NOV 12 - NOV 25	1.0	0.97
19	NOV 26 - DEC 9	1.0	1.13
20	DEC 10 - DEC 23	0.9	1.02
21	DEC 24 - JAN 6	1.0	1.05
22	JAN 7 - JAN 20	1.0	1.05
23	JAN 21 - FEB 3	1.0	1.05
24	FEB 4 - FEB 17	1.1	1.10
25	FEB 18 - MAR 3	0.8	0.97
26	MAR 4 - MAR 17	0.9	1.01

Summary for RUSSELL		
Average	1.0	1.05
Minimum	0.8	0.97
Maximum	1.1	1.15
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION SANFORD (RM MACDONALD) FLUORIDATOR W&T

OPERATOR Trevor Richardson CHEMICAL H2SiF6 25 %

PHONE 736-4327 NATURAL FLUORIDE 0.1

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.7	0.90
2	APR 2 - APR 15	1.1	1.20
3	APR 16 - APR 29	0.8	0.80
4	APR 30 - MAY 13	0.9	0.80
5	MAY 14 - MAY 27	1.0	1.00
6	MAY 28 - JUN 10	1.1	1.30
7	JUN 11 - JUN 24	0.8	0.60
8	JUN 25 - JUL 8	0.9	1.00
9	JUL 9 - JUL 22	1.0	1.10
10	JUL 23 - AUG 5	1.0	1.10
11	AUG 6 - AUG 19	1.0	1.10
12	AUG 20 - SEP 2	1.0	1.00
13	SEP 3 - SEP 16	1.0	1.00
14	SEP 17 - SEP 30	1.0	1.10
15	OCT 1 - OCT 14	1.0	1.10
16	OCT 15 - OCT 28	0.9	1.10
17	OCT 29 - NOV 11	0.9	1.10
18	NOV 12 - NOV 25	1.1	1.10
19	NOV 26 - DEC 9	1.0	1.10
20	DEC 10 - DEC 23	0.9	1.10
21	DEC 24 - JAN 6	1.1	1.10
22	JAN 7 - JAN 20	1.0	1.10
23	JAN 21 - FEB 3	1.0	1.30
24	FEB 4 - FEB 17	0.9	1.00
25	FEB 18 - MAR 3	0.9	0.80
26	MAR 4 - MAR 17	1.1	1.10

Summary for SANFORD (RM MACDONALD)

Average	1.0	1.04
Minimum	0.7	0.60
Maximum	1.1	1.30
Samples Above Limit	0	
Samples Below Limits	1	
% Outside Limits:	4%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION SAPOTAWEYAK
OPERATOR Horace Cook
PHONE 587-2125

FLUORIDATOR
CHEMICAL NaF 4 %
NATURAL FLUORIDE 0.31

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.7	NOT AVAILABLE
2	APR 2 - APR 15	0.6	NOT AVAILABLE
3	APR 16 - APR 29	0.8	NOT AVAILABLE
4	APR 30 - MAY 13	0.6	NOT AVAILABLE
5	MAY 14 - MAY 27	0.6	NOT AVAILABLE
6	MAY 28 - JUN 10	0.6	NOT AVAILABLE
7	JUN 11 - JUN 24	0.6	NOT AVAILABLE
8	JUN 25 - JUL 8	0.7	NOT AVAILABLE
9	JUL 9 - JUL 22	0.9	NOT AVAILABLE
10	JUL 23 - AUG 5	1.0	NOT AVAILABLE
11	AUG 6 - AUG 19	0.7	NOT AVAILABLE
12	AUG 20 - SEP 2	0.7	NOT AVAILABLE
13	SEP 3 - SEP 16	0.7	NOT AVAILABLE
14	SEP 17 - SEP 30	0.7	NOT AVAILABLE
15	OCT 1 - OCT 14	0.8	NOT AVAILABLE
16	OCT 15 - OCT 28	0.6	NOT AVAILABLE
17	OCT 29 - NOV 11	0.7	NOT AVAILABLE
18	NOV 12 - NOV 25	0.7	NOT AVAILABLE
19	NOV 26 - DEC 9	0.7	NOT AVAILABLE
20	DEC 10 - DEC 23	0.7	NOT AVAILABLE
21	DEC 24 - JAN 6	0.7	NOT AVAILABLE
22	JAN 7 - JAN 20	0.7	NOT AVAILABLE
23	JAN 21 - FEB 3	0.7	NOT AVAILABLE
24	FEB 4 - FEB 17	0.7	NOT AVAILABLE
25	FEB 18 - MAR 3	0.6	NOT AVAILABLE
26	MAR 4 - MAR 17	0.6	NOT AVAILABLE

Summary for SAPOTAWEYAK

Average	0.7
Minimum	0.6
Maximum	1.0
Samples Above Limit	0
Samples Below Limits	22
% Outside Limits:	85%
Number of Samples	26

Fluoride Control Data 2005 / 2006

LOCATION	SHILO	FLUORIDATOR	LMI Saturator
OPERATOR	Bill Burke	CHEMICAL	NaF 4 %
PHONE	765-4723	NATURAL FLUORIDE	0.05

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	1.05
2	APR 2 - APR 15	1.0	0.96
3	APR 16 - APR 29	1.0	1.14
4	APR 30 - MAY 13	1.0	0.94
5	MAY 14 - MAY 27	0.9	1.01
6	MAY 28 - JUN 10	1.0	1.05
7	JUN 11 - JUN 24	0.8	0.87
8	JUN 25 - JUL 8	0.8	0.97
9	JUL 9 - JUL 22	0.9	0.99
10	JUL 23 - AUG 5	1.0	0.79
11	AUG 6 - AUG 19	1.1	1.29
12	AUG 20 - SEP 2	1.0	1.01
13	SEP 3 - SEP 16	1.0	1.01
14	SEP 17 - SEP 30	1.1	1.12
15	OCT 1 - OCT 14	1.1	NOT AVAILABLE
16	OCT 15 - OCT 28	1.0	0.89
17	OCT 29 - NOV 11	0.9	1.16
18	NOV 12 - NOV 25	1.0	1.01
19	NOV 26 - DEC 9	0.9	1.13
20	DEC 10 - DEC 23	0.9	1.17
21	DEC 24 - JAN 6	1.1	1.13
22	JAN 7 - JAN 20	1.2	1.25
23	JAN 21 - FEB 3	NOT AVAILABLE	NOT AVAILABLE
24	FEB 4 - FEB 17	1.0	0.98
25	FEB 18 - MAR 3	0.9	1.07
26	MAR 4 - MAR 17	1.0	1.07

Summary for SHILO		
Average	1.0	1.04
Minimum	0.8	0.79
Maximum	1.2	1.29
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	25	

Fluoride Control Data 2005 / 2006

LOCATION SOMERSET
OPERATOR Remi Messner
PHONE 744-2179

FLUORIDATOR
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE .02

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.7	0.87
2	APR 2 - APR 15	1.0	1.10
3	APR 16 - APR 29	0.9	1.01
4	APR 30 - MAY 13	1.3	1.42
5	MAY 14 - MAY 27	0.6	0.87
6	MAY 28 - JUN 10	0.4	0.83
7	JUN 11 - JUN 24	0.5	0.82
8	JUN 25 - JUL 8	0.8	1.20
9	JUL 9 - JUL 22	0.6	1.01
10	JUL 23 - AUG 5	0.6	1.07
11	AUG 6 - AUG 19	0.7	1.02
12	AUG 20 - SEP 2	0.6	0.98
13	SEP 3 - SEP 16	0.6	1.15
14	SEP 17 - SEP 30	0.6	1.25
15	OCT 1 - OCT 14	0.9	1.16
16	OCT 15 - OCT 28	1.0	1.03
17	OCT 29 - NOV 11	0.5	1.09
18	NOV 12 - NOV 25	0.6	0.88
19	NOV 26 - DEC 9	0.8	1.02
20	DEC 10 - DEC 23	0.8	1.27
21	DEC 24 - JAN 6	0.9	1.29
22	JAN 7 - JAN 20	0.9	1.05
23	JAN 21 - FEB 3	0.9	0.96
24	FEB 4 - FEB 17	0.9	1.24
25	FEB 18 - MAR 3	0.7	0.98
26	MAR 4 - MAR 17	0.7	1.06

Summary for SOMERSET

Average	0.8	1.06
Minimum	0.4	0.82
Maximum	1.3	1.42
Samples Above Limit	1	
Samples Below Limits	14	
% Outside Limits:	58%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	SOURIS	FLUORIDATOR	LMI Saturator
OPERATOR	Don Bodin and Kelvin Kowalchuk	CHEMICAL	NaF 4 %
PHONE	483-3096	NATURAL FLUORIDE	0.19

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.8	0.97
2	APR 2 - APR 15	1.1	0.98
3	APR 16 - APR 29	0.9	0.99
4	APR 30 - MAY 13	1.0	1.08
5	MAY 14 - MAY 27	0.9	NOT AVAILABLE
6	MAY 28 - JUN 10	0.9	0.76
7	JUN 11 - JUN 24	0.8	0.87
8	JUN 25 - JUL 8	0.8	0.95
9	JUL 9 - JUL 22	0.9	0.86
10	JUL 23 - AUG 5	0.9	0.93
11	AUG 6 - AUG 19	NOT AVAILABLE	NOT AVAILABLE
12	AUG 20 - SEP 2	1.1	NOT AVAILABLE
13	SEP 3 - SEP 16	0.8	0.92
14	SEP 17 - SEP 30	0.9	0.92
15	OCT 1 - OCT 14	1.0	0.96
16	OCT 15 - OCT 28	0.7	1.15
17	OCT 29 - NOV 11	0.7	1.00
18	NOV 12 - NOV 25	1.1	1.18
19	NOV 26 - DEC 9	0.8	0.82
20	DEC 10 - DEC 23	0.9	1.10
21	DEC 24 - JAN 6	1.0	1.37
22	JAN 7 - JAN 20	1.1	1.25
23	JAN 21 - FEB 3	0.9	0.99
24	FEB 4 - FEB 17	1.4	1.36
25	FEB 18 - MAR 3	0.9	1.00
26	MAR 4 - MAR 17	0.6	0.85

Summary for SOURIS		
Average	0.9	1.01
Minimum	0.6	0.76
Maximum	1.4	1.37
Samples Above Limit	1	
Samples Below Limits	3	
% Outside Limits:	16%	
Number of Samples	25	

Fluoride Control Data 2005 / 2006

LOCATION	STEINBACH	FLUORIDATOR	Pulsatron
OPERATOR	Jason Hiebert	CHEMICAL	H2SiF6 25 %
PHONE	326-3708	NATURAL FLUORIDE	0.39

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.0	1.05
2	APR 2 - APR 15	1.0	1.06
3	APR 16 - APR 29	0.9	1.08
4	APR 30 - MAY 13	0.9	1.10
5	MAY 14 - MAY 27	0.9	1.07
6	MAY 28 - JUN 10	0.9	1.08
7	JUN 11 - JUN 24	0.9	1.14
8	JUN 25 - JUL 8	0.9	1.16
9	JUL 9 - JUL 22	0.9	1.16
10	JUL 23 - AUG 5	1.1	1.18
11	AUG 6 - AUG 19	0.9	1.18
12	AUG 20 - SEP 2	1.1	1.15
13	SEP 3 - SEP 16	1.0	1.04
14	SEP 17 - SEP 30	1.0	1.05
15	OCT 1 - OCT 14	1.0	1.09
16	OCT 15 - OCT 28	1.0	1.04
17	OCT 29 - NOV 11	0.9	1.04
18	NOV 12 - NOV 25	0.9	0.90
19	NOV 26 - DEC 9	0.5	0.54
20	DEC 10 - DEC 23	0.4	0.42
21	DEC 24 - JAN 6	0.5	0.50
22	JAN 7 - JAN 20	0.7	0.77
23	JAN 21 - FEB 3	0.7	0.83
24	FEB 4 - FEB 17	0.6	0.94
25	FEB 18 - MAR 3	0.7	0.87
26	MAR 4 - MAR 17	0.7	0.88

Summary for STEINBACH		
Average	0.8	0.97
Minimum	0.4	0.42
Maximum	1.1	1.18
Samples Above Limit	0	
Samples Below Limits	8	
% Outside Limits:	31%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	STEPHENFIELD	FLUORIDATOR	Prominent
OPERATOR	Replaced	CHEMICAL	H2SiF6 25 %
PHONE	828-3434	NATURAL FLUORIDE	0.2

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	1.01
2	APR 2 - APR 15	1.1	1.12
3	APR 16 - APR 29	1.1	1.05
4	APR 30 - MAY 13	1.2	1.25
5	MAY 14 - MAY 27	1.1	0.94
6	MAY 28 - JUN 10	1.1	0.97
7	JUN 11 - JUN 24	1.0	1.07
8	JUN 25 - JUL 8	1.2	1.04
9	JUL 9 - JUL 22	1.2	1.09
10	JUL 23 - AUG 5	1.1	1.06
11	AUG 6 - AUG 19	1.1	1.01
12	AUG 20 - SEP 2	1.1	1.25
13	SEP 3 - SEP 16	1.1	1.12
14	SEP 17 - SEP 30	1.1	1.44
15	OCT 1 - OCT 14	1.1	1.27
16	OCT 15 - OCT 28	0.6	1.24
17	OCT 29 - NOV 11	0.8	1.54
18	NOV 12 - NOV 25	0.9	1.07
19	NOV 26 - DEC 9	0.9	1.09
20	DEC 10 - DEC 23	0.9	1.03
21	DEC 24 - JAN 6	1.0	1.48
22	JAN 7 - JAN 20	1.0	0.99
23	JAN 21 - FEB 3	1.2	0.97
24	FEB 4 - FEB 17	1.2	1.05
25	FEB 18 - MAR 3	1.1	1.03
26	MAR 4 - MAR 17	1.0	1.12

Summary for STEPHENFIELD

Average	1.0	1.13
Minimum	0.6	0.94
Maximum	1.2	1.54
Samples Above Limit	0	
Samples Below Limits	1	
% Outside Limits:	4%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	SWAN RIVER	FLUORIDATOR	LMI A741
OPERATOR	Garry Kennedy	CHEMICAL	H2SiF6 25 %
PHONE	734-4628	NATURAL FLUORIDE	0.18

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	1.14
2	APR 2 - APR 15	1.0	1.12
3	APR 16 - APR 29	1.0	1.01
4	APR 30 - MAY 13	1.0	1.09
5	MAY 14 - MAY 27	1.0	1.18
6	MAY 28 - JUN 10	0.9	1.11
7	JUN 11 - JUN 24	0.9	1.08
8	JUN 25 - JUL 8	0.9	0.99
9	JUL 9 - JUL 22	0.9	0.90
10	JUL 23 - AUG 5	1.1	1.01
11	AUG 6 - AUG 19	0.9	1.04
12	AUG 20 - SEP 2	1.0	1.13
13	SEP 3 - SEP 16	1.0	0.96
14	SEP 17 - SEP 30	0.9	0.95
15	OCT 1 - OCT 14	1.0	1.02
16	OCT 15 - OCT 28	0.9	0.94
17	OCT 29 - NOV 11	0.9	1.15
18	NOV 12 - NOV 25	1.1	1.05
19	NOV 26 - DEC 9	1.0	1.07
20	DEC 10 - DEC 23	1.0	1.09
21	DEC 24 - JAN 6	1.0	0.98
22	JAN 7 - JAN 20	1.1	1.12
23	JAN 21 - FEB 3	1.1	1.12
24	FEB 4 - FEB 17	1.1	1.05
25	FEB 18 - MAR 3	1.0	1.08
26	MAR 4 - MAR 17	1.0	0.98

Summary for SWAN RIVER		
Average	1.0	1.05
Minimum	0.9	0.90
Maximum	1.1	1.18
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION THE PAS	FLUORIDATOR W&T 32-050
OPERATOR Ronald Stewart	CHEMICAL H2SiF6 25 %
PHONE 623-6338	NATURAL FLUORIDE 0.15

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.6	0.80
2	APR 2 - APR 15	1.1	0.08
3	APR 16 - APR 29	0.9	1.00
4	APR 30 - MAY 13	0.9	1.00
5	MAY 14 - MAY 27	0.9	0.90
6	MAY 28 - JUN 10	1.0	1.00
7	JUN 11 - JUN 24	0.9	1.10
8	JUN 25 - JUL 8	0.9	1.20
9	JUL 9 - JUL 22	0.9	1.12
10	JUL 23 - AUG 5	0.9	1.10
11	AUG 6 - AUG 19	0.9	1.00
12	AUG 20 - SEP 2	1.0	1.10
13	SEP 3 - SEP 16	1.0	1.00
14	SEP 17 - SEP 30	1.0	1.10
15	OCT 1 - OCT 14	1.0	1.10
16	OCT 15 - OCT 28	0.9	1.10
17	OCT 29 - NOV 11	0.9	1.10
18	NOV 12 - NOV 25	1.1	1.20
19	NOV 26 - DEC 9	1.0	1.10
20	DEC 10 - DEC 23	0.9	1.10
21	DEC 24 - JAN 6	1.0	1.10
22	JAN 7 - JAN 20	1.0	1.10
23	JAN 21 - FEB 3	1.1	1.10
24	FEB 4 - FEB 17	1.0	1.10
25	FEB 18 - MAR 3	1.0	1.20
26	MAR 4 - MAR 17	1.0	1.20

Summary for THE PAS

Average	1.0	1.04
Minimum	0.6	0.08
Maximum	1.1	1.20
Samples Above Limit	0	
Samples Below Limits	1	
% Outside Limits:	4%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	TREHERNE	FLUORIDATOR	LMI A741
OPERATOR	Ken Lawrence	CHEMICAL	Na2SiF6 (Dry)
PHONE	723-2850	NATURAL FLUORIDE	0.32

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	1.00
2	APR 2 - APR 15	1.1	1.00
3	APR 16 - APR 29	0.9	1.00
4	APR 30 - MAY 13	0.9	0.90
5	MAY 14 - MAY 27	0.8	1.00
6	MAY 28 - JUN 10	0.8	1.00
7	JUN 11 - JUN 24	0.8	1.00
8	JUN 25 - JUL 8	0.8	1.00
9	JUL 9 - JUL 22	0.9	0.90
10	JUL 23 - AUG 5	0.7	0.90
11	AUG 6 - AUG 19	0.9	1.00
12	AUG 20 - SEP 2	0.9	0.90
13	SEP 3 - SEP 16	0.7	0.90
14	SEP 17 - SEP 30	0.9	1.00
15	OCT 1 - OCT 14	1.0	1.00
16	OCT 15 - OCT 28	1.0	0.90
17	OCT 29 - NOV 11	0.9	1.00
18	NOV 12 - NOV 25	1.0	0.90
19	NOV 26 - DEC 9	1.0	1.00
20	DEC 10 - DEC 23	0.8	1.00
21	DEC 24 - JAN 6	1.0	1.00
22	JAN 7 - JAN 20	1.0	1.00
23	JAN 21 - FEB 3	1.0	1.00
24	FEB 4 - FEB 17	0.9	1.00
25	FEB 18 - MAR 3	1.0	0.90
26	MAR 4 - MAR 17	1.0	0.90

Summary for TREHERNE		
Average	0.9	0.97
Minimum	0.7	0.90
Maximum	1.1	1.00
Samples Above Limit	0	
Samples Below Limits	2	
% Outside Limits:	8%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	VIRDEN	FLUORIDATOR	LMI A751
OPERATOR	Norm Baxter	CHEMICAL	NaF 4 %
PHONE	748-3074	NATURAL FLUORIDE	0.44

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.0	1.32
2	APR 2 - APR 15	1.1	1.13
3	APR 16 - APR 29	1.2	1.47
4	APR 30 - MAY 13	1.0	1.20
5	MAY 14 - MAY 27	1.1	1.25
6	MAY 28 - JUN 10	1.0	0.99
7	JUN 11 - JUN 24	0.7	0.92
8	JUN 25 - JUL 8	0.7	0.93
9	JUL 9 - JUL 22	1.1	1.12
10	JUL 23 - AUG 5	0.8	0.95
11	AUG 6 - AUG 19	0.5	0.55
12	AUG 20 - SEP 2	0.5	0.59
13	SEP 3 - SEP 16	0.9	0.90
14	SEP 17 - SEP 30	1.0	1.06
15	OCT 1 - OCT 14	1.0	1.08
16	OCT 15 - OCT 28	0.9	0.88
17	OCT 29 - NOV 11	1.1	1.24
18	NOV 12 - NOV 25	1.2	1.11
19	NOV 26 - DEC 9	1.1	1.14
20	DEC 10 - DEC 23	1.0	1.09
21	DEC 24 - JAN 6	0.9	0.83
22	JAN 7 - JAN 20	0.9	1.01
23	JAN 21 - FEB 3	1.0	0.97
24	FEB 4 - FEB 17	0.9	0.79
25	FEB 18 - MAR 3	0.8	0.98
26	MAR 4 - MAR 17	1.0	0.78

Summary for VIRDEN		
Average	0.9	1.01
Minimum	0.5	0.55
Maximum	1.2	1.47
Samples Above Limit	0	
Samples Below Limits	4	
% Outside Limits:	15%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	WABOWDEN	FLUORIDATOR	Prominent
OPERATOR	Jack McIvor	CHEMICAL	H2SiF6 25 %
PHONE	689-2362	NATURAL FLUORIDE	< 0.10

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	1.3	1.20
2	APR 2 - APR 15	1.2	1.00
3	APR 16 - APR 29	1.3	1.30
4	APR 30 - MAY 13	1.2	1.00
5	MAY 14 - MAY 27	1.1	1.00
6	MAY 28 - JUN 10	0.7	0.80
7	JUN 11 - JUN 24	1.6	1.30
8	JUN 25 - JUL 8	1.0	1.10
9	JUL 9 - JUL 22	0.9	1.00
10	JUL 23 - AUG 5	0.9	0.90
11	AUG 6 - AUG 19	1.6	1.50
12	AUG 20 - SEP 2	1.1	1.20
13	SEP 3 - SEP 16	1.0	1.00
14	SEP 17 - SEP 30	0.9	0.90
15	OCT 1 - OCT 14	1.0	1.00
16	OCT 15 - OCT 28	1.0	NOT AVAILABLE
17	OCT 29 - NOV 11	1.0	1.10
18	NOV 12 - NOV 25	1.0	1.00
19	NOV 26 - DEC 9	0.9	1.00
20	DEC 10 - DEC 23	0.8	0.90
21	DEC 24 - JAN 6	0.9	0.80
22	JAN 7 - JAN 20	0.9	NOT AVAILABLE
23	JAN 21 - FEB 3	1.0	NOT AVAILABLE
24	FEB 4 - FEB 17	1.1	1.10
25	FEB 18 - MAR 3	1.3	NOT AVAILABLE
26	MAR 4 - MAR 17	1.1	NOT AVAILABLE

Summary for WABOWDEN		
Average	1.1	1.05
Minimum	0.7	0.80
Maximum	1.6	1.50
Samples Above Limit	5	
Samples Below Limits	1	
% Outside Limits:	23%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION	WINKLER	FLUORIDATOR	Prominent
OPERATOR	Retired	CHEMICAL	H2SiF6 25 %
PHONE	325-8711	NATURAL FLUORIDE	0.26

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.8	1.05
2	APR 2 - APR 15	1.1	0.89
3	APR 16 - APR 29	0.9	1.00
4	APR 30 - MAY 13	0.8	1.00
5	MAY 14 - MAY 27	0.8	0.97
6	MAY 28 - JUN 10	1.0	0.93
7	JUN 11 - JUN 24	0.8	0.93
8	JUN 25 - JUL 8	0.8	1.12
9	JUL 9 - JUL 22	0.9	1.17
10	JUL 23 - AUG 5	0.9	0.95
11	AUG 6 - AUG 19	0.8	0.82
12	AUG 20 - SEP 2	0.9	0.96
13	SEP 3 - SEP 16	1.0	0.97
14	SEP 17 - SEP 30	1.0	1.00
15	OCT 1 - OCT 14	1.0	NOT AVAILABLE
16	OCT 15 - OCT 28	0.9	1.12
17	OCT 29 - NOV 11	0.8	1.09
18	NOV 12 - NOV 25	1.0	1.11
19	NOV 26 - DEC 9	0.9	1.02
20	DEC 10 - DEC 23	0.8	1.14
21	DEC 24 - JAN 6	1.0	0.88
22	JAN 7 - JAN 20	0.9	0.96
23	JAN 21 - FEB 3	0.8	0.84
24	FEB 4 - FEB 17	0.9	1.00
25	FEB 18 - MAR 3	0.8	0.87
26	MAR 4 - MAR 17	1.0	1.15

Summary for WINKLER		
Average	0.9	1.00
Minimum	0.8	0.82
Maximum	1.1	1.17
Samples Above Limit	0	
Samples Below Limits	0	
% Outside Limits:	0%	
Number of Samples	26	

Fluoride Control Data 2005 / 2006

LOCATION WINNIPEG
OPERATOR Frank DeVries
PHONE 986-4752

FLUORIDATOR W&T
CHEMICAL H2SiF6 25 %
NATURAL FLUORIDE 0.1

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	NOT AVAILABLE
2	APR 2 - APR 15	1.1	NOT AVAILABLE
3	APR 16 - APR 29	0.9	NOT AVAILABLE
4	APR 30 - MAY 13	0.9	NOT AVAILABLE
5	MAY 14 - MAY 27	0.8	NOT AVAILABLE
6	MAY 28 - JUN 10	0.8	NOT AVAILABLE
7	JUN 11 - JUN 24	0.9	NOT AVAILABLE
8	JUN 25 - JUL 8	0.8	NOT AVAILABLE
9	JUL 9 - JUL 22	0.9	NOT AVAILABLE
10	JUL 23 - AUG 5	1.0	NOT AVAILABLE
11	AUG 6 - AUG 19	0.9	NOT AVAILABLE
12	AUG 20 - SEP 2	0.9	NOT AVAILABLE
13	SEP 3 - SEP 16	0.9	NOT AVAILABLE
14	SEP 17 - SEP 30	0.9	NOT AVAILABLE
15	OCT 1 - OCT 14	0.9	NOT AVAILABLE
16	OCT 15 - OCT 28	0.8	NOT AVAILABLE
17	OCT 29 - NOV 11	0.8	NOT AVAILABLE
18	NOV 12 - NOV 25	0.9	NOT AVAILABLE
19	NOV 26 - DEC 9	0.9	NOT AVAILABLE
20	DEC 10 - DEC 23	0.8	NOT AVAILABLE
21	DEC 24 - JAN 6	0.9	NOT AVAILABLE
22	JAN 7 - JAN 20	0.9	NOT AVAILABLE
23	JAN 21 - FEB 3	0.9	NOT AVAILABLE
24	FEB 4 - FEB 17	0.9	NOT AVAILABLE
25	FEB 18 - MAR 3	0.9	NOT AVAILABLE
26	MAR 4 - MAR 17	0.9	NOT AVAILABLE

Summary for WINNIPEG

Average	0.9
Minimum	0.8
Maximum	1.1
Samples Above Limit	0
Samples Below Limits	0
% Outside Limits:	0%
Number of Samples	26

Fluoride Control Data 2005 / 2006

LOCATION	WINNIPEGOSIS	FLUORIDATOR	LMI Saturator
OPERATOR	Dan Rempel	CHEMICAL	NaF 4 %
PHONE	656-4345	NATURAL FLUORIDE	0.15

	Sampling Period	Lab Fluoride	Operator Fluoride
1	MAR 19 - APR 1	0.9	0.58
2	APR 2 - APR 15	1.0	0.58
3	APR 16 - APR 29	0.9	0.73
4	APR 30 - MAY 13	0.9	0.72
5	MAY 14 - MAY 27	0.6	0.59
6	MAY 28 - JUN 10	0.6	0.57
7	JUN 11 - JUN 24	0.6	0.67
8	JUN 25 - JUL 8	0.6	0.69
9	JUL 9 - JUL 22	0.6	0.69
10	JUL 23 - AUG 5	1.1	0.84
11	AUG 6 - AUG 19	1.0	1.02
12	AUG 20 - SEP 2	1.1	1.08
13	SEP 3 - SEP 16	1.0	1.06
14	SEP 17 - SEP 30	1.0	0.98
15	OCT 1 - OCT 14	1.0	0.96
16	OCT 15 - OCT 28	1.2	0.93
17	OCT 29 - NOV 11	0.8	0.90
18	NOV 12 - NOV 25	1.0	0.91
19	NOV 26 - DEC 9	0.9	0.81
20	DEC 10 - DEC 23	0.7	0.70
21	DEC 24 - JAN 6	0.9	0.71
22	JAN 7 - JAN 20	0.9	0.72
23	JAN 21 - FEB 3	1.0	0.72
24	FEB 4 - FEB 17	0.9	0.69
25	FEB 18 - MAR 3	0.8	0.65
26	MAR 4 - MAR 17	0.9	0.64

Summary for WINNIPEGOSIS		
Average	0.9	0.77
Minimum	0.6	0.57
Maximum	1.2	1.08
Samples Above Limit	0	
Samples Below Limits	6	
% Outside Limits:	23%	
Number of Samples	26	